

RECEIVED

Form 238-7

3/95

AUG 13 1996

IDAHO DEPARTMENT OF WATER RESOURCES

WELL DRILLER'S REPORT

Use Typewriter or Ballpoint Pen

096880

Office Use Only	
Inspected by	TDK
Twp	46N Rge 4W Sec 09
1/4SW 1/4SE 1/4	
Lat:	Long:

1. DRILLING PERMIT NO.


Other IDWR No.

2. OWNER:

Name: Tim Blackstone
 Address: Rt 1 Box 156-B
 City: Plummer State: ID Zip: 83851

3. LOCATION OF WELL by legal description:

Sketch map location must agree with written location.



Twp. 46 North ☒ or South ☐
 Rge. 4 East ☐ or West ☒
 Sec. 9 1/4 SW 1/4 SE 1/4
 Gov't Lot _____ County Bernham
 Lat: _____ Long: _____

Address of Well Site from Plummer
 City Plummer
 (Give at least name of road or distance to Road or Landmark)
out of Plummer on L.

Lt. _____ Blk. _____ Sub. Name _____

4. USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other _____

5. TYPE OF WORK check all that apply (Replacement etc.)

☒ New Well ☐ Modify ☐ Abandonment ☐ Other _____

6. DRILL METHOD

☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other _____

7. SEALING PROCEDURES

SEAL/FILTER PACK			AMOUNT		METHOD
Material	From	To	Sacks or Pounds		
Bentonite	0	20	200 pnd.		pour

Was drive shoe used? ☒ Y ☐ N Shoe Depth(s) 20 ft.

Was drive shoe seal tested? ☒ Y ☐ N How? air

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
6	11	20	.25	Steel	☒	☐	☒	☐

Length of Headpipe _____ Length of Tailpipe _____

9. PERFORATIONS/SCREENS

☐ Perforations Method _____
☐ Screens Screen Type _____

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
						☐	☐
						☐	☐
						☐	☐

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:

220 ft. below ground Artesian pressure _____ lb.
 Depth flow encountered _____ ft. Describe access port or control devices: _____

11. WELL TESTS:

☐ Pump ☐ Bailor ☐ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
approx 15-20	Blown by Air (Leak)		

Water Temp. cold Bottom hole temp. cold

Water Quality test or comments: _____

Depth first Water Encountered 320

12. LITHOLOGIC LOG: (Describe repairs or abandonment)

Bore Dia.	From	To	Remarks: Lithology, Water Quality & Temperature	Y	N
8	0	3	Top Soil		☒
8	3	15	Broken Basalt		☒
8	15	20	hard Basalt		☒
6	20	320	hard Basalt	☒	
6	320	355	gray Clay		
6	355	390	Broken Basalt	☒	

Completed Depth 390 (Measurable)

Date: Started 8/6 Completed 8/7

13. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name Precision Drilling Firm No. 5508

Firm Official James L. ... Date 8/12/96

and Supervisor or Operator James L. ... Date _____

(Sign once if Firm Official & Operator)

FORWARD WHITE COPY TO WATER RESOURCES

SWSE 9 46N 4W