

WELL DRILLER'S REPORT

RECEIVED
JUN 23 2000

Office Use Only		
Inspected by		
Twp	Rge	Sec
1/4	1/4	1/4
Lat	:	Long

1. WELL TAG NO. D0013222

Drilling Permit No:

Other IDWR No.

2. OWNER

Name Ron Wisman

Address PO Box 344


City Plummer

State ID

Zip 83851

3. LOCATION OF WELL by legal description

sketch map location must agree with written location



Twp. 46



North or



South

Rge. 4



East or



West

Sec. 3



1/4 NW 1/4 SE 1/4

Gov't Lot

County

BENEWAH

Lat:

:

Long:

:

:

:

Address of Well Site 1635 Canyon Ridge La

City Plummer

(Give at least name of road + Distance to Road or Landmark)

Lt.

Blk.

Sub.

Name

4. USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation

☐ Thermal ☐ Injection ☐ Other

5. TYPE OF WORK check all that apply (Replacement, etc.)

☒ New Well ☐ Modify ☐ Abandonment ☐ Other

6. DRILL METHOD

☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other

7. SEALING PROCEDURES

SEAL/FILTER PACK			AMOUNT	METHOD
Material	From	To	Sacks or Pounds	
BENTONITE	0	18	7 sacks	overbore

Was drive shoe used? ☒ Y ☐ N Shoe Depth(s) 19

Was drive shoe seal tested? ☐ Y ☐ N How?

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
5	2	542	.250	steel	☒	☐	☒	☐
6	1	19	.250	steel	☒	☐	☒	☐

Length of Headpipe

Length of Tailpipe

9. PERFORATIONS/SCREENS

☒ Perforations Method torch

☐ Screens Screen Type

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
536	542	1/8 x 6	30	5	steel	☒	☐

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:

400 ft. below ground Artesian pressure lb.

Depth flow encountered ft. Describe access port or control devices:

11. WELL TESTS:

☐ Pump ☐ Bailer ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
50			1 hour

Water Temp. cold Bottom Hole Temp cold

Water Quality test or comments: clear

Depth first Water encountered 540

12. LITHOLOGIC LOG:(Describe repairs or abandonment)

				Water	
Bore Diam	From	To	Remarks: Lithology, Water Quality, Temperature	Y	N
8	0	3	Topsoil	☐	☒
8	3	6	Clay	☐	☒
8	6	10	Clay w/basalt	☐	☒
8	10	18	Basalt	☐	☒
6	18	290	Basalt Medium	☐	☒
6	290	320	Clay gray hard broken	☐	☒
6	320	330	Basalt w/clay	☐	☒
6	330	540	Basalt	☐	☒
6	540	545	Clay gray hard	☒	☐
	535	545	Gravel hole with 3/8" pea gravel	☐	☐

Completed Depth 545 (Measurable)
Date: Started 6/12/00 Completed 6/16/00

13. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name H2O Well Service, Inc. Firm No. 448

Firm Official [Signature] Date 6-21-00

and Supervisor or Operator [Signature] Date 6-20-00

(Sign Once if Firm Official and Operator)

46N 4W 3