RECEIVED

Form 238-7
3/95 JUL 11 1997

POSTED

NORTHERN REGION
IDWR

IDAHO DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORT

Use Typewriter or Ballpoint Pen

096884

Office Use Only
Inspected by _____
Twp____ Rge____ Sec ____
____1/4 ____1/4 ____1/4
Lat: : : Long: : :

1. DRILLING PERMIT NO. 95-97-N-62-____
Other IDWR No. _____

2. OWNER:
Name Mike Hixson
Address RT. 1, Box 930
City Plummer State Id Zip 83851

3. LOCATION OF WELL by legal description:
Sketch map location must agree with written location.

N / W / E / S — X

Twp. 46 North ☒ or South ☐
Rge. 4 East ☐ or West ☒
Sec. 15 ____ 1/4 (10 acres) SE 1/4 (40 acres) SE 1/4 (160 acres)
Gov't Lot ____ County Benewah
Lat: : : Long: : :
Address of Well Site 2 Miles South ON Acte Road City Plummer
(Give at least name of road + Distance to Road or Landmark)

Lt. _____ Blk. _____ Sub. Name _____

4. USE:
☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other _____

5. TYPE OF WORK check all that apply (Replacement etc.)
☒ New Well ☐ Modify ☐ Abandonment ☐ Other _____

6. DRILL METHOD
☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other _____

7. SEALING PROCEDURES

SEAL/FILTER PACK Material	From	To	AMOUNT Sacks or Pounds	METHOD
Bentonite	0	20	1 1/2 SKS	Pour

Was drive shoe used? ☒ Y ☐ N Shoe Depth(s) 98
Was drive shoe seal tested? ☒ Y ☐ N How? Air

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
6	+2	98	250	Steel	☒	☐	☒	☐
4	90	150	160	Pvc.	☐	☒	☐	☐
					☐	☐	☐	☐

Length of Headpipe _____ Length of Tailpipe _____

9. PERFORATIONS/SCREENS
☐ Perforations Method _____
☐ Screens Screen Type _____

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
90	150	7/16	60		Pvc	☐	☒
						☐	☐
						☐	☐

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:
105 ft. below ground Artesian pressure ____ lb.
Depth flow encountered 135 ft. Describe access port or control devices: Well Cap

11. WELL TESTS:
☐ Pump ☐ Bailer ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
15			1 hr.

Water Temp. Cold Bottom hole temp. _____
Water Quality test or comments: Clear
Depth first Water Encountered 135

12. LITHOLOGIC LOG: (Describe repairs or abandonment)

Bore Dia.	From	To	Remarks: Lithology, Water Quality & Temperature	Water Y	Water N
8	0	14	Brown Clay		
	14	69	Red Clay		
	69	87	Soft Gray Clay		
	87	98	Med " "		
	98	135	Gray Shale		
	135	142	Soft Broken Gray Shale	Y	
	142	150	Med Gray Shale		

Completed Depth 150 (Measurable)
Date: Started 7/7/97 Completed 7/7/97

13. DRILLER'S CERTIFICATION
I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name All-Ways Drilling Firm No. 510
Firm Official Stanley K Wolfe Date 7/8/97
and
Supervisor or Operator R. Dysert Date 7/8/97
(Sign once if Firm Official & Operator)

SESE 15 46N 4W

FORWARD WHITE COPY TO WATER RESOURCES