

IDAHO DEPARTMENT OF WATER RESOURCES

WELL DRILLER'S REPORT

Office Use Only			
Inspected by _____			
Twp _____	Rge _____	Sec _____	
1/4 _____	1/4 _____	1/4 _____	
Lat: _____	Long: _____		

1. WELL TAG NO. D0056271Drilling Permit No: 856627

Other IDWR No. _____

2. OWNER

Well Number: _____

Name KOZELUH, ONDREJ & MICHELLE 1482Address 2011 E. 56TH AVE.City SPOKANE State WA Zip 99223

3. LOCATION OF WELL by legal description

sketch map location must agree with written location

N		E	

Twp. 54N ☒ North or ☐ South
Rge. 05W ☐ East or ☒ West
Sec. 30 1/4 SW 1/4 SW 1/4
Gov't Lot _____ County BONNER
Latitude: N47.59.675 Longitude: W117.01.200

Address of Well Site Prairie Road
City Blanchard

(Give at least name of road + Distance to Road or Landmark)

Lt. _____ Blk. _____ Sub. Name _____

4. USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other _____

5. TYPE OF WORK check all that apply (Replacement, etc.)

☒ New Well ☐ Modify ☐ Abandonment ☐ Other _____

6. DRILL METHOD

☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other _____

7. SEALING PROCEDURES

SEAL/FILTER PACK			AMOUNT Sacks or Pounds	METHOD
Material	From	To		
BENTONITE	0	18	500 LBS	OVERBORE

Was drive shoe used? ☒ Y ☐ N Shoe Depth(s) 68Was drive shoe seal tested? ☐ Y ☒ N How? _____

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
6	+2	68	.250	STEEL	☒	☐	☒	☐
4	-5	400	.200	PVC	☐	☒	☐	☐

Length of Headpipe _____ Length of Tailpipe _____

9. PERFORATIONS/SCREENS

Perforations Method SKILLSAW
☐ Screens Screen Type _____

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
-380	400	1/8 X 8	48	4	PVC	☐	☒

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:

70 ft. below ground Artesian pressure _____ lb.

Depth flow encountere 69 ft. Describe access port or control devices: _____

11. WELL TESTS:

☐ Bailer ☒ Air ☐ Flowing Artesian
 Yield gal./min. Drawdown Pumping Level Time

2			

Water Temp. COLD Bottom Hole Temp COLDWater Quality test or comments: GOODDepth first Water encountered 69

12. LITHOLOGIC LOG:(Describe repairs or abandonment)

Bore Diam	From	To	Remarks: Lithology, Water Quality, Temperature	Water	Y	N
10	0	3	Top Soil	☐	☒	☐
10	3	25	Sandy Tan Clay	☐	☒	☐
8	25	60	Brown Sand	☐	☒	☐
8	60	68	Tan Decomposed Granite	☐	☒	☐
6	68	140	Grv/Wht Granite 2 gpm	☐	☐	☐
6	140	215	Blk/Wht Granite	☐	☒	☐
6	215	400	Drk Grv/Wht Granite	☐	☒	☐

RECEIVED

JUL 06 2009

IDWR/North

SCANNED

JAN 16 2014

 Completed Depth 400 (Measurable)
 Date: Started 6/9/2009 Completed 6/11/2009

13. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name H2O WellService, Inc. Firm No. 448Firm Official [Signature] Date 6-15-09

and

Supervisor or Operator [Signature] Date 6/12/2009

JIM McLESLIE

(Sign Once if Firm Official and Operator)

54N 05W 30