RECEIVED
DEC 05 1995
IDWR

Form 238-7
3/95

POSTED

IDAHO DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORT

Use Typewriter or Ballpoint Pen

Office Use Only
Inspected by TDK
Twp 54N Rge 5W Sec 08
NW 1/4 NW 1/4 SE 1/4
Lat: : : Long: : :

1. DRILLING PERMIT NO. 96-95-N-0349
Other IDWR No.

2. OWNER:
Name Roger Young
Address P.O.Box 73
City Blanchard State ID Zip 83804

3. LOCATION OF WELL by legal description:
Sketch map location must agree with written location.

N / W / E / S

Twp. 54 North ☒ or South ☐
Rge. 5 East ☐ or West ☒
Sec. 8, 10 acres 1/4 NW 40 acres 1/4 SE 160 acres 1/4
Gov't Lot County Bonner
Lat: : : Long: : :
Address of Well Site Hwy 41
City Blanchard
(Give at least name of road + Distance to Road or Landmark)

Lt. Blk. Sub. Name

4. USE:
☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other

5. TYPE OF WORK check all that apply (Replacement etc.)
☒ New Well ☐ Modify ☐ Abandonment ☐ Other

6. DRILL METHOD
☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other

7. SEALING PROCEDURES

SEAL/FILTER PACK Material	From	To	AMOUNT Sacks or Pounds	METHOD
bentonite	0	38	10	overbore

Was drive shoe used? ☒Y ☐N Shoe Depth(s)
Was drive shoe seal tested? ☐Y ☐N How?

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
6	+2	33	250	steel	☒	☐	☒	☐
4	-20	280	160	PVC	☐	☒	☐	☐
					☐	☐	☐	☐

Length of Headpipe Length of Tailpipe

9. PERFORATIONS/SCREENS
☒ Perforations Method saw
☐ Screens Screen Type

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
200	220	1/8x4	10		PVC	☐	☒
260	300	1/8x4	20		PVC	☐	☒
						☐	☐

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:
80 ft. below ground Artesian pressure lb.
Depth flow encountered ft. Describe access port or control devices: cap

NWSE 8 54N 5W

11. WELL TESTS:
☐ Pump ☐ Bailer ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
5		295	1hr

Water Temp. Bottom hole temp.
Water Quality test or comments:
Depth first Water Encountered

12. LITHOLOGIC LOG: (Describe repairs or abandonment)

Bore Dia.	From	To	Remarks: Lithology, Water Quality & Temperature	Water Y	Water N
8	0	5	decomposed granite sand		
	5	15	" " "		
	15	28	firm brown&white		
	28	32	soft brown&white		
	32	38	firm salt&pepper		
6	38	45	" " "		
	45	90	firm brown&white		
	90	120	firm salt&pepper		
	120	125	soft salt&pepper		
	125	195	firm black&white		
	195	205	soft salt&pepper	X	
	205	215	firm black&white		
	215	230	soft brown&white		
	230	245	firm salt&pepper		
	245	249	soft salt&pepper		
	249	260	firm black&white		
	260	270	soft salt&pepper, some green		
	270	300	firm salt&pepper		

MICROFILMED
MAR 09 1999

Completed Depth 300 (Measurable)
Date: Started 10/20/95 Completed 10/20/95

13. DRILLER'S CERTIFICATION
I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

SCANNED
JAN 22 2014

Firm Name Bronson Water Wells Firm No. 360
Firm Official N D Bronson Date 10/23/95
and
Supervisor or Operator Clint Bronson Date
(Sign once if Firm Official & Operator)

FORWARD WHITE COPY TO WATER RESOURCES