

IDAHO DEPARTMENT OF WATER RESOURCES WELL DRILLER'S REPORT

Office Use Only			
Inspected by _____			
Twp _____	Rge _____	Sec _____	
1/4	1/4	1/4	
Lat : : _____		Long: : : _____	

1. WELL TAG NO. D0022974

DRILLING PERMIT N

788294

Other IDWR No _____

2. OWNER:

Name **Pat Doyle**

Address P O Box 1267

City Rathdrum

State ID

Zip 83858

3. LOCATION OF WELL by legal description:

N		Twp 54N	North ☒ or South ☐
Rge 05W		East ☐ or West ☒	
Sec 26		1/4 NE 1/4 NE 1/4	
		10 Ac 40 Ac 160 Ac	
Gov't Lot _____		County Bonner	
Lat _____		Long _____	
Address of Well Site: (see next line)			

Hwy 414 miles north of Spirit Lake "Deer Meadow Estates" City _____

Lot _____ Blk _____ Sub. Name (see next line) _____

4. USE:

- ☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other _____

5. TYPE OF WORK check all that apply (Replacement etc.)

- ☒ New Well ☐ Modify ☐ Abandonment ☐ Other _____

6. DRILL METHOD

- ☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other _____

7. SEALING PROCEDURES

SEAL/FILTER PACK			Amount	Method
Material	From	To	Sacks/Lbs	
BENTONITE	0	18	8 SACKS	DRY POIR

Drive Shoe Used? ☐ Y ☒ N Shoe Depth(s) _____

Drive Shoe Seal Tested? ☐ Y ☒ N How? _____

8. CASING/LINER

Diam	From	To	Gauge	Material	Casing	Liner	Weld	Thrded
6	2	158	0.250	STEEL	☒	☐	☒	☐
					☐	☐	☐	☐
					☐	☐	☐	☐

Length Headpipe _____ Length Tailpipe _____

9. PERFORATIONS/SCREENS

☐ Perforations? Method _____

☐ Screens? Screen Type _____

From	To	Slot	Nmbr	Diam	Material	Casing	Liner
						☐	☐
						☐	☐
						☐	☐

10. STATIC WATER LEVEL or ARTESIAN PRESSURE

108 ft. below ground. Artesian pressure _____ lb.

Depth flow encountered 108 ft. Describe access port or

control devices: STEEL CAP WELDED

54N 5W 26

11. WELL TESTS:

- ☐ Pump ☐ Bailor ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pump Level	Time
25 GPM	100%	158	1 HOUR

Water Temp. _____ COLD Bottom hole temp. _____ COLD

Water Quality test or comments: (below) Depth first Water Encountered 108

CLEAR, COLD, NO SMELL

12. LITHOLOGIC LOG (Describe repairs or abandonment)

Bore Diam	From	To	Remarks: Lithology, Water Quality and Temperature	Water	
				Y	N
8	0	32	Sand & Gravel 3/4" minus	☐	☒
8	32	75	Sand - Brown - Course	☐	☒
8	75	85	Clay - Brown	☐	☒
8	85	105	Clay - Gray	☐	☒
8	105	135	Sand - Brown - Course	☒	☐
8	135	158	Sand - Gravel 1" minus	☒	☐

RECEIVED

02 29 2002

IDWR/North

Completed Depth 158 (Measurable)

Date: Started 10/24/02 Completed 10/24/02

13. DRILLERS CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm United Drilling Inc.

Firm No 414

Name

Firm Official and

Supervisor or Operator Jason C. Beckham

Date 10/25/02

Date 10/25/02

SCANNED
JAN 22 2014