

IDaho DEPARTMENT OF WATER RESOURCES

POSTED

WELL DRILLER'S REPORT 097416

Use Typewriter or Ballpoint Pen

Office Use Only

Inspected by _____

Twp. _____ Rge. _____ Sec. _____

1/4 _____ 1/4 _____ 1/4 _____

Lat. : : Long. : :

1. DRILLING PERMIT NO. 96-97-N-75

Other IDWR No. _____

2. OWNER:

Name Ron HoffmanAddress Bayview Rd. & Hwy 95City Careywood State Id Zip 83809

3. LOCATION OF WELL by legal description:

Sketch map location must agree with written location.

N					
	X				
S					

Twp. 56 North ☒ or South ☐
 Rge. 3 East ☐ or West ☒
 Sec. 13 1/4 SE 1/4 SW 1/4 NW
 Gov't Lot _____ County Banner
 Lat. : : Long. : :
 Address of Well Site Bayview Rd & Hwy 95 City _____
 (Give at least name of road + Distance to Road or Landmark)

Lt. _____ Blk. _____ Sub. Name _____

4. USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other _____

5. TYPE OF WORK check all that apply (Replacement etc.)

☒ New Well ☐ Modify ☐ Abandonment ☐ Other _____

6. DRILL METHOD

☐ Air Rotary ☒ Cable ☐ Mud Rotary ☐ Other _____

7. SEALING PROCEDURES

SEAL/FILTER PACK			AMOUNT		METHOD
Material	From	To	Sacks or Pounds		
Bentonite	0	20	4		Over Bore 8" casing

Was drive shoe used? ☒ Y ☐ N Shoe Depth(s) _____Was drive shoe seal tested? ☐ Y ☒ N How? _____

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
6	4	52	2.8	Steel	☒	☐	☒	☐

Length of Headpipe _____ Length of Tailpipe _____

9. PERFORATIONS/SCREENS

☐ Perforations Method _____

☒ Screens Screen Type Stainless steel

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
52	57	20		6"		☐	☐

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:

5 ft. below ground Artesian pressure - lb.

Depth flow encountered _____ ft. Describe access port or

control devices: Well Seal

11. WELL TESTS:

☐ Pump ☒ Bailer ☐ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
30	0	-5'	3 hr

Water Temp. Cold Bottom hole temp. _____

Water Quality test or comments: _____

12. LITHOLOGIC LOG: (Describe repairs or abandonment)

Bore Dia.	From	To	Remarks: Lithology, Water Quality & Temperature	Water	Y	N
8	0	2	Top Soil			X
8	2	18	Sand			X
6	18	50	Quick sand		X	
6	50	57	pea gravel		X	

SCANNED

JAN 30 2014

Completed Depth 57 (Measurable)Date: Started 6-5-97 Completed 6-6-97

13. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name Bob Pitts & sons Firm No. 235Firm Official Dale Pitts Date 6-9-97

and

Supervisor or Operator _____ Date _____

(Sign once if Firm Official & Operator)

SE NW 13 56 N 3 W

FORM 238-7 WHEN COPY TO WATER RESOURCES