

IDAHO DEPARTMENT OF WATER RESOURCES

WELL DRILLER'S REPORT


Office Use Only
Inspected by _____
Twp. _____ Rge. _____ Sec. _____
Lat. 1/4 1/4 1/4
Long. _____

1. WELL TAG NO. D0022307
Drilling Permit No: 777486
Other IDWR No. _____

2. OWNER
Name HAWKS, ERNIE Well Number: 405
Address P.O. BOX 47

City CARREYWOOD State ID Zip 83809

3. LOCATION OF WELL by legal description
sketch map location must agree with written location



Twp. 54N ☒ North or ☐ South
Rge. 3W ☐ East or ☒ West
E Sec. 25 NE 1/4 NE 1/4 1/4

Gov't Lot _____ County BONNER

Lat: _____ Long: _____

Address of Well Site 333 COUNTRY WOOD
City CARREYWOOD

(Give at least name of road + Distance to Road or Landmark)

Lt. _____ Blk. _____ Sub. Name _____

4. USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other _____

5. TYPE OF WORK check all that apply (Replacement, etc.)

☒ New Well ☐ Modify ☐ Abandonment ☐ Other _____

6. DRILL METHOD

☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other _____

7. SEALING PROCEDURES

SEAL/FILTER PACK			AMOUNT	METHOD
Material	From	To	Sacks or Pounds	
BENTONITE	0	20	5 BAGS	OVERBORE

Was drive shoe used? ☒ Y ☐ N Shoe Depth(s) 145

Was drive shoe seal tested? ☐ Y ☐ N How? _____

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
6	+2	145	.250	STEEL	☒	☐	☒	☐
4	-100	800	.160	PVC	☐	☒	☐	☐

Length of Headpipe _____ Length of Tailpipe _____

9. PERFORATIONS/SCREENS

☒ Perforations Method SKILL SAW

☐ Screens Screen Type _____

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
740	760	1/8 X 6	70	4	PVC	☐	☒
780	800	1/8 X 6	70	4	PVC	☐	☒

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:

200 ft. below ground Artesian pressure _____ lb.
Depth flow encountered 680 ft. Describe access port or
control devices: _____

11. WELL TESTS:

Yield gal./min.	Drawdown	Pumping Level	Time
2.5			1 HR

Water Temp. COLD Bottom Hole Temp COLD

Water Quality test or comments: GOOD

Depth first Water encountered 680

12. LITHOLOGIC LOG:(Describe repairs or abandonment)

Bore Diam	From	To	Remarks: Lithology, Water Quality, Temperature	Water	
				Y	N
				☐	☐
8	0	12	Top Soil w/Gravel	☐	☐
8	12	145	Sand & Gravel	☐	☐
6	145	230	Granite Salt & Pepper w/apx. 1 gpm @	☒	☐
6	230	680	Granite Salt & Pepper	☐	☐
6	680	685	Soft Granite w/Water	☒	☐
6	685	800	Granite Salt & Pepper	☐	☐

SCANNED

JAN 3 1 2014

Completed Depth 800 (Measurable)
Date: Started 5/25/02 Completed 5/30/02

13. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards
were complied with at the time the rig was removed.

Firm Name H2O WellService, Inc. Firm No. 448

Firm Official [Signature] Date 6-3-02

and
Supervisor or Operator [Signature] Date 6-3-02
(Sign Once if Firm Official and Operator)

Louie Hanner

54N 3W 25