USE TYPEWRITER OR BALL POINT PEN

State of Idaho
Department of Water Resources

WELL DRILLER'S REPORT

RECEIVED
SEP 26 1975
Department of Water Resources
Northern District Office

State law requires that this report be filed with the Director, Department of Water Resources within 30 days after the completion or abandonment of the well.

1. WELL OWNER

Name AL BERENS

Address FERNWOOD

Owner's Permit No. 92-75-N-2

2. NATURE OF WORK

☑ New well ☐ Deepened ☐ Replacement

☐ Abandoned (describe method of abandoning)

3. PROPOSED USE

☑ Domestic ☐ Irrigation ☐ Test ☐ Other (specify type)

☐ Municipal ☐ Industrial ☐ Stock ☐ Waste Disposal or Injection

4. METHOD DRILLED

☐ Cable ☑ Rotory ☐ Dug ☐ Other

5. WELL CONSTRUCTION

Diameter of hole 6 inches Total depth 65 feet

Casing schedule: ☑ Steel ☐ Concrete

Thickness	Diameter	From	To
.750 inches	6 inches	+ 2 feet	19 feet
____ inches	____ inches	____ feet	____ feet
____ inches	____ inches	____ feet	____ feet
____ inches	____ inches	____ feet	____ feet
____ inches	____ inches	____ feet	____ feet

Was casing drive shoe used? ☑ Yes ☐ No

Was a packer or seal used? ☐ Yes ☑ No

Perforated? ☐ Yes ☑ No

How perforated? ☐ Factory ☐ Knife ☐ Torch

Size of perforation ____ inches by ____ inches

Number	From	To
____ perforations	____ feet	____ feet
____ perforations	____ feet	____ feet
____ perforations	____ feet	____ feet

Well screen installed? ☐ Yes ☑ No

Manufacturer's name ____

Type ____ Model No. ____

Diameter ____ Slot size ____ Set from ____ feet to ____ feet

Diameter ____ Slot size ____ Set from ____ feet to ____ feet

Gravel packed? ☐ Yes ☑ No Size of gravel ____

Placed from ____ feet to ____ feet

Surface seal depth 18 Material used in seal ☐ Cement grout ☑ Puddling clay ☑ Well cuttings

Seating procedure used ☐ Slurry pit ☐ Temporary surface casing ☑ Overbore to seal depth

6. LOCATION OF WELL

Sketch map location must agree with written location.



Subdivision Name ____

Lot No. ____ Block No. ____

County BENEWAH

SE ¼ SW ¼ Sec. 23, T. 44 N, R. 1 E/W

7. WATER LEVEL

Static water level 35 feet below land surface

Flowing? ☐ Yes ☐ No G.P.M. flow ____

Temperature ____ ° F. Quality ____

Artesian closed-in pressure ____ p.s.i.

Controlled by ☐ Valve ☐ Cap ☐ Plug

8. WELL TEST DATA

☐ Pump ☐ Bailer ☑ Other AIR

Discharge G.P.M.	Draw Down	Hours Pumped
6	0	

9. LITHOLOGIC LOG

Hole Diam.	Depth From	Depth To	Material	Water Yes	Water No
8	0	3	Overburden		✓
8	3	8	Clay Brown		✓
	8	62	Basalt Hard		✓
	62	64	Basalt Broken	✓	
	64	65	Clay Grey		

10. Work started 9/10/75 finished 9/11/75

11. DRILLERS CERTIFICATION

Firm Name Associated Well Firm No. 245

Address Box 773 C'd'A Date 9/12/75

Signed by (Firm Official) Bud Thornton

and

(Operator) Gary Smith

USE ADDITIONAL SHEETS IF NECESSARY FORWARD THE WHITE COPY TO THE DEPARTMENT