

3/95 SEP 29 1997

DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORT

Use Typewriter or Ballpoint Pen

Office Use Only
Inspected by _____
Twp _____ Rge _____ Sec _____
_____ 1/4 _____ 1/4 _____ 1/4
Lat: : : Long: : :

NORTHERN REGION

1. DRILLING PERMIT NO. 92-97-N-17 D000-3208
Other IDWR No. _____

2. OWNER:

Name Judith E. Bowers
Address Sielle Hoyt Ave.
City Everett State W. Zip 98201

3. LOCATION OF WELL by legal description:

Sketch map location must agree with written location.

N
 W E S
 Twp. 44 North ☒ or South ☐
 Rge. 3 East ☐ or West ☒
 Sec. 35 1/4 N/W 1/4 S/W 1/4
 Gov't Lot _____ County Brazoria 10 acres 40 acres 160 acres
 Lat. : : Long. : :
 Address of Well Site 4 miles west on
Smiths Rd. from Hwy. 6 City Euclid
 (Give at least name of road - Distance to Road or Landmark)

Lt. _____ Blk. _____ Sub. Name _____

4. USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other _____

5. TYPE OF WORK check all that apply (Replacement etc.)

☒ New Well ☐ Modify ☐ Abandonment ☐ Other _____

6. DRILL METHOD

☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other_____

7. SEALING PROCEDURES

SEAL/FILTER PACK			AMOUNT	METHOD
Material	From	To	Sacks or Pounds	
Bentonite	0'	27'	300 lbs	pour dry

Was drive shoe used? ☒ Y ☐ N Shoe Depth(s) 89'
Was drive shoe seal tested? ☒ Y ☐ N How? Air

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
10"	+2'	89'	.250	Steel	☒	☐	☒	☐
4"	80'	264'	100psi	PVC	☐	☒	☐	☐
					☐	☐	☐	☐

Length of Headpipe +2' Length of Tailpipe 89'

9. PERFORATIONS/SCREENS

☐ Perforations Method _____

☐ Screens Screen Type _____

From	To	Slot Size	Number	Diameter	Material	Casing	Line
						☐	☐
						☐	☐
						☐	☐

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:

91' ft. below ground Artesian pressure _____ lb.
Depth flow encountered 243' ft. Describe access port or
control devices: _____

11. WELL TESTS:

☐ Pump ☐ Bailer ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
9 gpm			1 hr.

Water Temp. _____ Bottom hole temp. _____

Water Quality test or comments: Cold & Clean

Depth first Water Encountered 185'

12. LITHOLOGIC LOG: (Describe repairs or abandonment) Water

[illegible]

Completed Depth 2164 (Measurable)
Date: Started 9-9-97 Completed 9-11-97

13. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name Allways Drilling Firm No. 510

Firm Official Frank F Wolff Date 7/16/97

and

Supervisor or Operator [Signature] Date 9-12-97
(Sign once if Firm Official & Operator)

(Sign once if Firm Official & Operator)

FORWARD WHITE COPY TO WATER RESOURCES