RECEIVED
APR 12 1967
Department of Reclamation

REPORT OF WELL DRILLER
State of Idaho

State law requires that this report shall be filed with the State Reclamation Engineer within 30 days after completion or abandonment of the well.

WELL OWNER:
Name GEORGE W. YEARout
Address RFD 1 ST. MARIES IDAHO
92-67-N-2
Owner's Permit No.
NATURE OF WORK (check): Replacement well ☐
New well ☒ Deepened ☐ Abandoned ☐
Water is to be used for: HOUSE HOLD
METHOD OF CONSTRUCTION: Rotary ☐ Cable ☒
Dug ☐ Other
(explain)
CASING SCHEDULE: Threaded ☐ Welded ☒
6 "Diam. from 0 ft. to 14 ft.
"Diam. from ft. to ft.
"Diam. from ft. to ft.
"Diam. from ft. to ft.
Thickness of casing: 1/4 Material:
Steel ☒ concrete ☐ wood ☐ other ☐
(explain)
PERFORATED? Yes ☐ No ☒ Type of perforator used:


Size of perforations: " by "
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.
WAS SCREEN INSTALLED? Yes ☐ No ☒
Manufacturer's name
Type Model No.
Diam. Slot size Set from ft. to ft.
Diam. Slot size Set from ft. to ft.

CONSTRUCTION: Well gravel packed? Yes ☐
No. ☒ size of gravel Gravel placed from ft. to ft. Surface seal provided? Yes ☐ No ☐ To what depth? ft. Material used in seal:

Did any strata contain unusable water? Yes ☐
No. ☒ Type of water:
Depth of strata ft. Method of sealing strata off:

Surface casing used? Yes ☐ No. ☐
Cemented in place? Yes ☐ No ☐

Locate well in section



LOCATION OF WELL: County Benewah
NW¼ SE¼ Sec. 4 T. 44 N/S R. 3 E/W

Size of drilled hole: 6" Total depth of well: 55 Standing water level below ground: 19 Temp. Fahr. ° Test delivery: 8 gpm or cfs Pump? ☒ Bail ☐
Size of pump and motor used to make test:

Length of time of test: ONE Hrs. Min.
Drawdown: 15 ft. Artesian pressure: ft. above land surface Give flow cfs or gpm. Shutoff pressure:
Controlled by: Valve ☐ Cap ☐ Plug ☐
No control ☐ Does well leak around casing? Yes ☐ No ☐

DEPTH FROM FEET	DEPTH TO FEET	MATERIAL	WATER YES OR NO
			NO
0	6	CLAY	
6	55	BLACK BASALT	YES
		Water at 54 ft.	

Work started: MARCH 4
Work finished: APRIL 1

Well Driller's Statement: This well was drilled under my supervision and this report is true to the best of my knowledge.
Name: WILMET FREDERICK
Address: SPIRIT LAKE IDAHO
Signed by: Wilmet Frederick
License No. 317 Date: April 10
71

Use other side for additional remarks

USGS

SCANNED

92