

RECEIVED

DEC 4 2002

IDAHO DEPARTMENT OF WATER RESOURCES

WELL DRILLER'S REPORT

IDWR/North

1. WELL TAG NO. D 0022936

DRILLING PERMIT NO. 788928

Water Right or Injection Well No.

2. OWNER:

Name Eldon and Ruby Garner
Address P.O. Box 308-250 Peole
City Fernwood State ID Zip 83833

3. LOCATION OF WELL by legal description:

You must provide address or Lot, Blk, Sub. or Directions to well.

Twp. 43 North or South
Rge. 1 East or West
Sec. 11 1/4 1/4 1/4 1/4
Gov't Lot County Benewah

Lat. : Long. :
Address of Well Site Little Carpenter Cr. and
Love Lane City Fernwood

Lt. Blk. Sub. Name

4. USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other

5. TYPE OF WORK check all that apply (Replacement etc.)

☒ New Well ☐ Modify ☐ Abandonment ☐ Other

6. DRILL METHOD:

☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other

7. SEALING PROCEDURES

Seal Material	From	To	Weight / Volume	Seal Placement Method
Bentonite	0	40	14 SX	Pour Around Pipe

Was drive shoe used? ☒ Y ☐ N Shoe Depth(s) 109'
Was drive shoe seal tested? ☒ Y ☐ N How? Air

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
6"	+1	-109	250	Steel	☒	☐	☒	☐
4"	-6	-350	160	PVC	☐	☒	☐	☐

Length of Headpipe Length of Tailpipe

Packer ☐ Y ☐ N Type

9. PERFORATIONS/SCREENS PACKER TYPE

Perforation Method Drill

Screen Type & Method of Installation

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
310	330	1"	10	4"	PVC	☐	☒

10. FILTER PACK

Filter Material	From	To	Weight / Volume	Placement Method
-----------------	------	----	-----------------	------------------

11. STATIC WATER LEVEL OR ARTESIAN PRESSURE:

110 ft. below ground Artesian pressure lb.

Depth flow encountered 220 ft. Describe access port or control devices:

well cap

43 N 1 W 11

Office Use Only			
Well ID No. _____			
Inspected by _____			
Twp _____	Rge _____	Sec _____	
1/4 _____	1/4 _____	1/4 _____	
Lat: _____	Long: _____	_____	

12. WELL TESTS:

☐ Pump ☐ Bailor ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
2 gpm.	air lift from	350'	

Water Temp. 56° Bottom hole temp.

Water Quality test or comments: clear no odor

Depth first Water Encounter 220

13. LITHOLOGIC LOG: (Describe repairs or abandonment)

Bore Dia.	From	To	Remarks: Lithology, Water Quality & Temperature	Y	N
8"	0	3	Clay - Tan Sandy		
	3	95	Shale - multi color Broken		
	95	119	Shale - gray		
6"	119	220	Shale - gray		
	220	225	Shale - gray - Broken w/ water		
			2 gpm		
	225	294	Shale gray		
	294	350	Shale gray Hard		

Completed Depth 350 (Measurable)

Date: Started 11-7-02 Completed 11-11-02

14. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name All-Ways Drilling Inc. Firm No. 510

Principal Driller Alvin Carris Date 12-6-02

Driller or Operator II Date

Operator I Stanley Kewele Date 12-6-02

Principal Driller and Rig Operator Required.
Operator must have signature of Driller/Operator II.

FORWARD WHITE COPY TO WATER RESOURCES