

NORTHWEST REGION
IDWR

1. DRILLING PERMIT NO. 92-94-N-0033-000
Other IDWR No. _____

2. OWNER:

Name Bill West
Address P.O. Box 6701
City Bakersfield State CA Zip 93386

3. LOCATION OF WELL by legal description:

Sketch map location must agree with written location.

N
 W E S
 Twp. 45 North ☒ or South ☐
 Rge. 1 East ☐ or West ☒
 Sec. 19 1/4 5/E 1/4 5/E 1/4
 Gov't Lot _____ County Benzonia

Address of Well Site 1 mile west on
Flat Creek Road City St. Marys
(Give at least name of road + distance to road or landmark)

Lt.	Blk.	Sub. Name
-----	------	-----------

4. PROPOSED USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other

5. TYPE OF WORK

☒ New Well ☐ Modify or Repair ☐ Replacement ☐ Abandonment

6. DRILL METHOD

☐ Mud Rotary ☒ Air Rotary ☐ Cable ☐ Other _____

7. SEALING PROCEDURES

SEAL/FILTER PACK			AMOUNT	METHOD
Material	From	To	Sacks or Pounds	
Bentonite	0	18	55KS	Pour

Was drive shoe used? ☒ Y ☐ N Shoe Depth(s) _____

Was drive shoe seal tested? Y ☐ N ☒ How? _____

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
6	12	18	250		☒	☐	☒	☐
					☐	☐	☐	☐
					☐	☐	☐	☐

Length of Headpipe _____ Length of Tailpipe _____

9. PERFORATIONS/SCREENS

☐ Perforations Method _____

☐ Screens Screen Type _____

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
						☐	☐
						☐	☐
						☐	☐

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:

305 ft. below ground Artesian pressure — lb.

Depth flow encountered 330 ft. Describe access port or control devices: CAI

SESE 19 45N 1W

11. WELL TESTS:

☐ Pump ☐ Bailer ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
30			1.5 hrs

Water Temp. cold Bottom hole temp. _____

Water Quality test or comments: Clear no odor

12. LITHOLOGIC LOG: (Describe repairs or abandonment) Water

[illegible]

13. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name All ways Drilling Inc Firm No. 510

Firm Official Sam Kudo Date 11/22/94

and

Supervisor or Operator Robert Hegity Date 11/22/94
(Sign once if Firm Official or Operator)