

STATE OF IDAHO
DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORTState law requires that this report be filed with the Director, Department of Water Resources
within 30 days after the completion or abandonment of the well.USE TYPEWRITER OR
BALLPOINT PEN

1. WELL OWNER

Name Edna Hanson
Route 1, Box 50-A
Address Harrison, Idaho 83833
Owner's Permit No. 92-83-N-15

7. WATER LEVEL

Static water level 40 feet below land surface.
Flowing? ☐ Yes ☒ No G.P.M. flow _____
Artesian closed-in pressure _____ p.s.i.
Controlled by: ☐ Valve ☐ Cap ☐ Plug
Temperature _____ of. Quality _____
Describe artesian or temperature zones below.

2. NATURE OF WORK

- ☒
- New well
- ☐
- Deepened
- ☐
- Replacement
-
- ☐
- Abandoned (describe abandonment procedures such as materials, plug depths, etc. in lithologic log)

8. WELL TEST DATA

☐ Pump ☐ Bailer ☒ Air ☐ Other _____

Discharge G.P.M.	Pumping Level	Hours Pumped
10+ GPM - ESTIMATED AIRLIFT		

3. PROPOSED USE

- ☒
- Domestic
- ☐
- Irrigation
- ☐
- Test
- ☐
- Municipal
-
- ☐
- Industrial
- ☐
- Stock
- ☐
- Waste Disposal or Injection
-
- ☐
- Other _____ (specify type)

9. LITHOLOGIC LOG

Bore Diam.	Depth		Material	Water	
	From	To		Yes	No
10"	0	1	Top soil, Brown		X
10"	1	20	Sand, brown & boulders		X
6"	20	40	Basalt, broken & boulders		X
6"	40	50	Basalt, broken w/cloudy water	X	
6"	50	60	Basalt, broken	X	

4. METHOD DRILLED

- ☒
- Rotary
- ☒
- Air
- ☐
- Hydraulic
- ☐
- Reverse rotary
-
- ☐
- Cable
- ☐
- Dug
- ☐
- Other _____

5. WELL CONSTRUCTION

Casing schedule: ☒ Steel ☐ Concrete ☐ Other _____

Thickness	Diameter	From	To
.250 inches	5 inches	1 feet	58 feet
.250 inches	6 inches	1 feet	40 feet
_____ inches	_____ inches	_____ feet	_____ feet
_____ inches	_____ inches	_____ feet	_____ feet

Was casing drive shoe used? ☒ Yes ☐ NoWas a packer or seal used? ☒ Yes ☐ NoPerforated? ☒ Yes ☐ NoHow perforated? ☐ Factory ☐ Knife ☒ TorchSize of perforation 1/8 inches by 6 inches

Number	From	To
18 perforations	45 feet	58 feet
_____ perforations	_____ feet	_____ feet
_____ perforations	_____ feet	_____ feet

Well screen installed? ☐ Yes ☒ No

Manufacturer's name _____

Type _____ Model No. _____

Diameter _____ Slot size _____ Set from _____ feet to _____ feet

Diameter _____ Slot size _____ Set from _____ feet to _____ feet

Gravel packed? ☒ Yes ☐ No ☐ Size of gravel peaPlaced from 40 feet to 60 feetSurface seal depth 30 Material used in seal: ☐ Cement grout☒ Bentonite ☐ Pudding clay ☐ _____Sealing procedure used: ☐ Slurry pit ☐ Temp. surface casing☒ Overbore to seal depthMethod of joining casing: ☐ Threaded ☒ Welded ☐ Solvent

Weld

☐ Cemented between strata

Describe access port _____

NO PVC Liner Installed

6" Drive shoe Installed

RECEIVED


006263

AUG 29 1983

Department of Water Resources
Northern District Office

6. LOCATION OF WELL

Sketch map location must agree with written location.

Subdivision Name _____Lot No. 1 Block No. _____County BENEWAH
_____ 1/4 _____ 1/4 Sec. 17 T. 46N N/S, R. 2W E/W.

10.

Work started 8/22/83 finished 8/24/83

11. DRILLERS CERTIFICATION

I/We certify that all minimum well construction standards were
complied with at the time the rig was removed.Firm Name PONDEROSA DRILLING Firm No. 228E. 6010 Broadway
Address Spokane, WA 99212 Date 8/24/83Signed by (Firm Official) W. Scott Barratt

and

(Operator) Doug Lang