

Form 23 MAY 20 2002
11/97

WELL DRILLER'S REPORT

IDWR/North

1. WELL TAG NO. D 00022193
 DRILLING PERMIT NO. - - 7-76335
 Other IDWR No. _____

2. OWNER: Pat Suchoski
Name _____
Address HCOL Box 55
City St. Maries ID State ID Zip 83861

3. LOCATION OF WELL by legal description:

Sketch map location must agree with written location.



Twp. 46 North ☒ or South ☐
 Rge. 2 East ☐ or West ☒
 Sec. 20 $\frac{1}{4}$ 40 $\frac{1}{4}$ 80 $\frac{1}{4}$ 160
 Gov't Lot _____ County Benewah
 Lat. : : Long. : :
 Address of Well Site Cherry Creek
Tamarack - Appela City St. Maries
 (Give at least name of road + Distance to Road or Landmark)

Lt.	B/k.	Sub.	Name
-----	------	------	------

4. USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other

5. TYPE OF WORK check all that apply (Replacement etc.)

 New Well ☐ Modify ☐ Abandonment ☐ Other _____

6. DRILL METHOD

☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other

7. SEALING PROCEDURES

SEAL/FILTER PACK			AMOUNT	METHOD
Material	From	To	Sacks or Pounds	
Bentonite	0	40	8 sr	Pour Around Pipe

Was drive shoe used? ☒ Y ☐ N Shoe Depth(s) 40'
Was drive shoe seal tested? ☒ Y ☐ N How? A/E

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
6"	+2	-40	250	Steel	☒	☐	☐	☐
4"	-5	-245	160	PVC	☐	☒	☐	☐
					☐	☐	☐	☐

Length of Headpipe Length of Tailpipe

9. PERFORATIONS/SCREENS

Perforations Method Drill
Screens Screen Type

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
205	245	1"	35	4"	PU2	☐	☒
						☐	☐
						☐	☐

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:

143 ft. below ground Artesian pressure _____ lb.
Depth flow encountered 194 ft. Describe access port or
control devices: well cap

46 N 2W 20 FORWARD WHITE COPY TO WATER RESOURCES

11. WELL TESTS:

☐ Pump ☐ Bailer ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
25 g.p.m.	Air lift	from 245'	

Water Temp. 48° Bottom hole temp. _____

Water Quality test or comments: Clear no odor

Depth first Water Encounter / 75

12. LITHOLOGIC LOG: (Describe repairs or abandonment) Water

Bore Dia.	From	To	Remarks: Lithology, Water Quality & Temperature	Y	N
8"	0	4	Top Soil		
	4	10	Basalt Broken		
	10	40	Gray Basalt		
6"	40	175	Basalt Gray	✓	
			3 gpm @ 175		
	175	194	Basalt Gray		
	194	245	Basalt - Gray & Brown w/ water	✓	
			22 gpm		
			25 gpm @ 245		

Completed Depth 243 (Measurable)
Date: Started 4-17-62 Completed 4-18-62

13. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name All-Ways Drilling Inc Firm No. 510

Firm Official Stanley Wolf Date 5-16-02

Driller or Operator Alvin Carris Date 5-3-02

(Sign once if Firm Official & Operator)