

IDAHO DEPARTMENT OF WATER RESOURCES

WELL DRILLER'S REPORT

Use Typewriter or Ballpoint Pen

Office Use Only
Inspected by _____
Twp. _____ Rge. _____ Sec. _____
1/4 _____ 1/4 _____ 1/4 _____
Lat: _____ Long: _____

Tag # 3829
1. DRILLING PERMIT NO. _____
Other IDWR No. _____
2. OWNER: 92-98-N-8
Name: Donald Slater
Address: P.O. Box 61
City: Santa State: Id Zip: 83866

3. LOCATION OF WELL by legal description:

Sketch map location must agree with written location.

North
W E S
Twp. 44 North ☒ or South ☐
Rge. 1 East ☐ or West ☒
Sec. 27 1/4 NE 1/4 NW 1/4
Gov't Lot _____ County: Benewah
Lat: _____ Long: _____
Address of Well Site: Sheep Cr. Rd. at
Tison Cr. Y City: Sant

Lt. _____ Blk. _____ Sub. Name _____

4. USE:

- ☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other _____

5. TYPE OF WORK check all that apply (Replacement etc.)

- ☒ New Well ☐ Modify ☐ Abandonment ☐ Other _____

6. DRILL METHOD

- ☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other _____

7. SEALING PROCEDURES

SEAL/FILTER PACK			AMOUNT	METHOD
Material	From	To	Sacks or Pounds	
Bentonite	0	44	400#	Four dry

Was drive shoe used? ☒ Y ☐ N Shoe Depth(s) 45'
Was drive shoe seal tested? ☒ Y ☐ N How? Air

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
6"	+2	45'	.280	Steel	☒	☐	☒	☐
4"	5	165'	160	PVC	☐	☒	☐	☐

Length of Headpipe: N/A Length of Tailpipe: N/A

9. PERFORATIONS/SCREENS

- ☒ Perforations Method: open hole - drill
☐ Screens Screen Type: _____

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
85'	165'	1/4"	150	4"	PVC	☐	☒

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:

94 ft. below ground Artesian pressure: N/A lb.
Depth flow encountered: 138 ft. Describe access port or control devices: well cap

44 N 1 W S27

11. WELL TESTS:

- ☐ Pump ☐ Bailor ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
8			1 hr

Water Temp. Cold Bottom hole temp. Cold
Water Quality test or comments: Clean

12. LITHOLOGIC LOG: (Describe repairs or abandonment) Water

Bore Dia.	From	To	Remarks: Lithology, Water Quality & Temperature	Y	N
8"	0	6	Top soil		☒
8"	6	15	clay red		☒
8"	15	44	clay brown		☒
6"	44	138	Basalt rock		☒
6"	138	175	sand gray fine		☒

Completed Depth: 165' (Measurable)
Date: Started 6-1-98 Completed 6-2-98

13. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name: Always Drilling Firm No: 510
Firm Official: Stanley K. Wolfe Date: 6-2-98
and
Supervisor or Operator: [Signature] Date: 6-2-98
(Sign once if Firm Official & Operator)

FORWARD WHITE COPY TO WATER RESOURCES