Form 238-7
6/93


IDAHO DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORT

Use Typewriter
or
Ball Point Pen

1. DRILLING PERMIT NO. 92-94-N-5-000
Other IDWR No.

2. OWNER:
Name Dave FuBanks
Address 840 Irvine Road
City Simi Valley State Ca Zip 93065

3. LOCATION OF WELL by legal description:
Sketch map location must agree with written location.



T. 44 North ☒ or South ☐
R. 1 East ☐ or West ☒
Sec. 18, ____ 10 acres 1/4 NW 40 acres 1/4 NW 160 acres 1/4
Gov't Lot ____ County Benewah

Address of Well Site Mountain Pastel Drive
Highway 6
(Give at least Direction + Distance to Road or Landmark)

Lot No. ____ Block No. ____ Subd. Name ____

4. PROPOSED USE:
☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other ____

5. TYPE OF WORK
☒ New Well ☐ Modify or Repair ☐ Replacement ☐ Abandonment

6. DRILL METHOD
☐ Mud Rotary ☒ Air Rotary ☐ Cable ☐ Other ____

7. SEALING PROCEDURES

SEAL/FILTER PACK Material	From	To	AMOUNT Sacks or Pounds	METHOD
Bentonite	0	78	16 SKS	Pour

Was drive shoe seal tested? Y☐ N☐ How? ____

8. CASING/LINER:

Diameter	From	To	Guage	Casting	Liner	Steel	Plastic	Welded	Threaded
6	0	78	.250			☒	☐	☒	☐
						☐	☐	☐	☐
						☐	☐	☐	☐
						☐	☐	☐	☐

Final location of shoes 78
Top Packer or Headpipe ____ Bottom Tailpipe ____

9. PERFORATIONS/SCREENS
☐ Perforations Method ____
☐ Screens Type ____ Material ____

From	To	Slot Size	Number	Diameter	Tele/Pipe Size	Casting	Liner
						☐	☐
						☐	☐
						☐	☐
						☐	☐

NW NW 18 44N 1W

10. WELL TESTS:
☐ Pump ☐ Bailer ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Depth	Time
30			1 hr.

Temperature of water Cold Was a water analysis done? Yes ☐ No ☒
By whom? ____
Water Quality (odor, etc.) No odor, Clear, Cold
Bottom Hole Temperature ____

11. STATIC WATER LEVEL:
30 ft. below surface Depth artesian flow found ____
Artesian pressure ____ lb. Describe access port ____
Describe Controlling Devices: ____

12. LITHOLOGIC LOG: (Describe repairs or abandonment)

Bore Dia.	From	To	Remarks: Lithology, Water Quality & Temperature	GPM	SWL
8	0	74	Brown Clay		
	74	78	Gray Shale		
6	78	330	Gray Shale	30	30

RECEIVED
JUN 29 1994
NORTHERN REGION
IDWR

Date: Started 5/2/94 Completed 6/6/94

13. DRILLER'S CERTIFICATION
I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name All-Ways Drilling Inc Firm No. 510
Firm Official Stanley K Wolfe Date 6/20/94
and
Supervisor or Operator Robert Pratt Date 6/8/94
(Sign once if Firm Official & Operator)

FORWARD WHITE COPY TO WATER RESOURCES