

ENT'D

☐ Pump ☐ Bailer ☒ Air ☐ Flowing Artesian

Sketch map location must agree with written location.

(Give at least Direction + Distance to Road or Landmark)

Lot No. _____ Block No. _____ Subd. Name _____

4. PROPOSED USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other _____

5. TYPE OF WORK

☒ New Well ☐ Modify or Repair ☐ Replacement ☐ Abandonment

6. DRILL METHOD

☐ Mud Rotary ☒ Air Rotary ☐ Cable ☐ Other

7. SEALING PROCEDURES

SEAL/FILTER PACK			AMOUNT	METHOD
Material	From	To	Sacks or Pounds	
Bentonite	0	20	300 lbs	Temp. Casing

Was drive shoe seal tested? Y ☐ N ☒ How? _____

8. CASING/LINER:

Diameter	From	To	Gauge	Casting	Liner	Steel	Plastic	Welded	Threaded
6"	+1	19	.250	~~X~~		~~X~~	☐	~~X~~	☐
4"	0	240			X	☐	~~X~~	☐	☐
						☐	☐	☐	☐
						☐	☐	☐	☐

Final location of shoes _____

Top Packer or Headpipe _____ Bottom Tailpipe _____

9. PERFORATIONS/SCREENS

☒ Perforations Method Skill Saw

☐ Screens Type _____ Material _____

From	To	Slot Size	Number	Diameter	Tele/Pipe Size	Casting	Liner
100	140	1/8X7	60			☐	☒
						☐	☐
						☐	☐
						☐	☐

SW NE ZI 4SN IW

Yield gal./min.	Drawdown	Pumping Depth	Time
10		140	1hr

Temperature of water _____ Was a water analysis done? Yes ☐ No ☐

By whom?

Water Quality (odor, etc.)

Bottom Hole Temperature

11. STATIC WATER LEVEL:

30 ft. below surface Depth artesian flow found

Artesian pressure _____ lb. Describe access port _____

Describe Controlling Devices: _____

12. LITHOLOGIC LOG: (Describe repairs or abandonment)

[illegible]

13. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name Ponderosa Drilling & Firm No. 228

Development, Inc.

Firm Official [Signature] Date 7-19-93

and W. Scott Barratt

Supervisor or Operator Brad Forman Date 7-19-93
Brad Forman

(Sign once if Firm Official & Operator)

FORWARD WHITE COPY TO WATER RESOURCES