

WELL DRILLER'S REPORT

State law requires that this report be filed with the Director, Department of Water Resources within 30 days after the completion or abandonment of the well.

1. WELL OWNER

Name Buster Reagan
Address 726 MAIN
Owner's Permit No. 92-77-N-11

2. NATURE OF WORK

- ☒
- New well
- ☐
- Deepened
- ☐
- Replacement
-
- ☐
- Abandoned (describe method of abandoning)

3. PROPOSED USE

- ☒
- Domestic
- ☐
- Irrigation
- ☐
- Test
- ☐
- Other (specify type)
-
- ☐
- Municipal
- ☐
- Industrial
- ☐
- Stock
- ☐
- Waste Disposal or Injection

4. METHOD DRILLED

- ☐
- Cable
- ☒
- Rotary
- ☐
- Dug
- ☐
- Other

5. WELL CONSTRUCTION

Diameter of hole 6 inches Total depth 215 feet
Casing schedule: ☐ Steel ☐ Concrete

Thickness	Diameter	From	To
<u>250</u> inches	<u>8</u> inches	<u>1</u> feet	<u>20</u> feet
_____ inches	<u>6</u> inches	<u>20</u> feet	<u>215</u> feet
_____ inches	_____ inches	_____ feet	_____ feet
_____ inches	_____ inches	_____ feet	_____ feet
_____ inches	_____ inches	_____ feet	_____ feet

- Was casing drive shoe used?
- ☐
- Yes
- ☒
- No
-
- Was a packer or seal used?
- ☐
- Yes
- ☒
- No
-
- Perforated?
- ☐
- Yes
- ☒
- No

How perforated? ☐ Factory ☐ Knife ☐ Torch

Size of perforation _____ inches by _____ inches

Number	From	To
_____ perforations	_____ feet	_____ feet
_____ perforations	_____ feet	_____ feet
_____ perforations	_____ feet	_____ feet

Well screen installed? ☐ Yes ☒ No

Manufacturer's name _____

Type _____ Model No. _____


Diameter _____ Slot size _____ Set from _____ feet to _____ feet

Diameter _____ Slot size _____ Set from _____ feet to _____ feet

Gravel packed? ☐ Yes ☒ No Size of gravel _____
Placed from _____ feet to _____ feetSurface seal depth 20 Material used in seal Bentwhite ☐ Cement grout
☐ Puddling clay ☒ Well cuttingsSealing procedure used ☐ Sherry pit ☐ Temporary surface casing
☐ Overbore to seal depth

6. LOCATION OF WELL

Sketch map location must agree with written location.



Subdivision Name _____

Lot No. _____ Block No. _____

County BENEWAHSW 1/4 SW 1/4 Sec. 20, T.46 N., R. 2 W. 8 E. W.

7. WATER LEVEL

Static water level 130 feet below land surface
Flowing? ☐ Yes ☒ No G.P.M. flow 15
Temperature _____ ° F. Quality _____
Artesian closed-in pressure _____ p.s.i.
Controlled by ☐ Valve ☐ Cap ☐ Plug

8. WELL TEST DATA

- ☒
- Pump
- ☐
- Bailer
- ☐
- Other

Discharge G.P.M.	Draw Down	Hours Pumped
<u>18</u>	<u>—</u>	<u>1/2</u>
_____	_____	_____
_____	_____	_____

9. LITHOLOGIC LOG

Hole Diam.	Depth		Material	Water	
	From	To		Yes	No
8	0	1	TOP SOIL		X
8	1	10	BROWN CLAY		X
8	10	132	BROKEN BASALT		X
6	132	153	HARD PAN CLAY BROWN		X
6	153	202	BROKEN BASALT	X	
6	202	215	HARD BASALT		X

RECEIVED
JUL 11 1977Department of Water Resources
Northern District Office

RECEIVED

JUL 20 1977

Department of Water Resources
Northern District Office

10.

Work started 7-6-77 finished 7-6-77

11. DRILLERS CERTIFICATION

Firm Name CARMAN Development Firm No. _____Address 6610 Broadway Date 7-7-77Signed by (Firm Official) Harold O'Connell
and John Carman
(Operator) Daniel O'Connell