

IDAHO DEPARTMENT OF WATER RESOURCES

WELL DRILLER'S REPORT 076491

RECEIVED

1. WELL TAG NO. D 0010788

DRILLING PERMIT NO. DEC 01 1999

Other IDWR No. 92-99-N-36

2. OWNER:

IDWR/North

Name NORVAL POOLER

Address 327 Finn Creek Rd

City FERNWOOD State ID Zip 83830

3. LOCATION OF WELL by legal description:

Sketch map location must agree with written location.

POSTED

Twp. 44N	North ☒ or South ☐
Rge. 1E	East ☒ or West ☐
Sec. 32	1/4 5/4 1/4 5/4
Gov't Lot	County Benewah
Lat:	Long:

Address of Well Site Finn Creek Rd
City FERNWOOD

Lt. Blk. Sub. Name

4. USE:

- ☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other

5. TYPE OF WORK check all that apply (Replacement etc.)

- ☒ New Well ☐ Modify ☐ Abandonment ☐ Other

6. DRILL METHOD

- ☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other

7. SEALING PROCEDURES

SEAL/FILTER PACK		AMOUNT		METHOD
Material	From	To	Sacks or Pounds	
Bentonite	0	80	7	poured

Was drive shoe used? ☒ N Shoe Depth(s) 128

Was drive shoe seal tested? ☒ N How? AIR

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
6"	0	128		Steel	☒	☐	☒	☐

Length of Headpipe 42 Length of Tailpipe 128

9. PERFORATIONS/SCREENS

Perforations Method DRILLED
Screens Screen Type

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
355	285	1/4	80	1/4	PVC	☐	☒
285	15				PVC	☐	☒

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:

100 ft. below ground Artesian pressure lb.

Depth flow encountered 105 ft. Describe access port or control devices: well cap

11. WELL TESTS:

- ☐ Pump ☐ Bailer

Yield gal./min.	Drawdown	Pumping Level	Time
45 gpm			

Water Temp. Cold

Bottom hole temp.

Water Quality test or comments: cloudy

Depth first Water Encounter 100

12. LITHOLOGIC LOG: (Describe repairs or abandonment) Water

Bore Dia.	From	To	Remarks: Lithology, Water Quality & Temperature	Y	N
8"	0	125	Soil yellow clay gravel	1	
6"	125	180	yellow clay gravel mix	1	
6"	180	210	decomposed granit		
6"	210	260	salt pepper granit		
6"	260	270	green granit		
6"	270	300	green granit QUANT mix		
6"	300	310	green granit		
6"	310	375	salt pepper granit		

Customer wanted water that was cased out so we perforated casing allowing 20 gpm more upper water which was 511 ft clay Perforated 117' to 120'

Completed Depth 375 (Measurable)
Date: Started 11/8/99 Completed 11/10/99

13. DRILLER'S CERTIFICATION

I/we certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name Allway's Drill & Pump Firm No. 510

Firm Official [Signature] Date 11/30/99

and Driller or Operator [Signature] Date 11/12/99

(Sign once if Firm Official & Operator)

44N 1E 32

FORWARD WHITE COPY TO WATER RESOURCES