

State of Idaho
Department of Water Resources

State law requires that this report be filed with the Director, Department of Water Resources within 30 days after the completion or abandonment of the well.

RECEIVED

DEC 3 1976

Department of Water Resources
Northern District Office

1. WELL OWNER

Name Ray Schoenick
Name Shirl Bircher
Address Route 2, St. Mary's Idaho
Owner's Permit No. 94-76-N-10

2. NATURE OF WORK

☒ New well ☐ Deepened ☐ Replacement

☐ Abandoned (describe method of abandoning)

3. PROPOSED USE

☒ Domestic ☐ Irrigation ☐ Test ☐ Other (specify type) _____
☐ Municipal ☐ Industrial ☐ Stock ☐ Waste Disposal or Injection

4. METHOD DRILLED

☐ Cable ☐ Rotary ☐ Dug ☐ Other

5. WELL CONSTRUCTION

Diameter of hole 6 inches Total depth 200 feet
Casing schedule: ☒ Steel ☐ Concrete

Thickness		Diameter		From		To	
250	inches	6	inches	1	feet	48	feet
	inches		inches		feet		feet
	inches		inches		feet		feet
	inches		inches		feet		feet
	inches		inches		feet		feet

Was casing drive shoe used? ☒ Yes ☐ No
Was a packer or seal used? ☐ Yes ☒ No
Perforated? ☐ Yes ☒ No
How perforated? ☐ Factory ☐ Knife ☐ Torch
Size of perforation _____ inches by _____ inches

Number	From	To
_____ perforations	_____ feet	_____ feet
_____ perforations	_____ feet	_____ feet
_____ perforations	_____ feet	_____ feet

Well screen installed? ☐ Yes ☒ No

Manufacturer's name _____
Type _____ Model No. _____
Diameter _____ Slot size _____ Set from _____ feet to _____ feet
Diameter _____ Slot size _____ Set from _____ feet to _____ feet

Gravel packed? ☐ Yes ☒ No Size of gravel _____
Placed from _____ feet to _____ feet

Surface seal depth 258 Material used in seal ☐ Cement grout
☒ Bentonite ☐ Puddling clay ☐ Well cuttings
 Sealing procedure used ☐ Sherry pit ☐ Temporary surface casing
☐ Overbore to seal depth

6. LOCATION OF WELL

Sketch map location must agree with written location

Kootenai County.

Subdivision Name none

Lot No. _____ Block No. _____
S2SE4NW4SE4
Sec 25. T47N R3W B1M.

County Kootenai

NW SE4
NE SW 1/4 Sec. 25 T. 47N N/S. R. 3W B1M

7. WATER LEVEL

Static water level 100 feet below land surface
Flowing? ☐ Yes ☒ No G.P.M. flow _____
Temperature _____ ° F. Quality _____
Artesian closed-in pressure _____ p.s.i.
Controlled by ☐ Valve ☐ Cap ☐ Plug

8. WELL TEST DATA

☒ Pump ☐ Bailer ☐ Other

Discharge G.P.M.	Draw Down	Hours Pumped
------------------	-----------	--------------

9. LITHOLOGIC LOG

[illegible]

10. Work started 9-25-76 finished 9-25-76

II. DRILLERS CERTIFICATION

Firm Name Carman Dev. Company Firm No. 228
Address E 6010 Broadway, Sp. Wn 99206 Date 9-27-7
Signed by (Firm Official) John Carman
and
(Operator) John Carman

USE ADDITIONAL SHEETS IF NECESSARY

FORWARD THE WHITE COPY TO THE DEPARTMENT