

WELL DRILLER'S REPORT

State law requires that this report be filed with the Director, Department of Water Resources within 30 days after the completion or abandonment of the well.

1. WELL OWNER

Name John R. Millikin

Address #6 Meadowhurst, St. Maries, ID 83861

Owner's Permit No. 91-80-N-2

2. NATURE OF WORK

☒ New well ☐ Deepened ☐ Replacement
☐ Abandoned (describe method of abandoning)

3. PROPOSED USE

☒ Domestic ☐ Irrigation ☐ Test ☐ Municipal
☐ Industrial ☐ Stock ☐ Waste Disposal or Injection
☐ Other (specify type)

4. METHOD DRILLED

☒ Rotary ☒ Air ☐ Hydraulic ☐ Reverse rotary
☐ Cable ☐ Dug ☐ Other

5. WELL CONSTRUCTION

Casing schedule: ☒ Steel ☐ Concrete ☐ Other

Thickness	Diameter	From	To
<u>.250</u> inches	<u>6</u> inches	<u>1</u> feet	<u>116</u> feet

Was casing drive shoe used? ☒ Yes ☐ No
Was a packer or seal used? ☐ Yes ☒ No
Perforated? ☐ Yes ☒ No
How perforated? ☐ Factory ☐ Knife ☐ Torch
Size of perforation inches by inches

Number	From	To

Well screen installed? ☐ Yes ☒ No
Manufacturer's name
Type Model No.
Diameter Slot size Set from feet to feet
Diameter Slot size Set from feet to feet
Gravel packed? ☐ Yes ☒ No ☐ Size of gravel
Placed from feet to feet
Surface seal depth 97' Material used in seal: ☐ Cement grout
☒ Puddling clay ☐ Well cuttings
Sealing procedure used: ☐ Slurry pit ☐ Temp. surface casing
☒ Overbore to seal depth
Method of joining casing: ☐ Threaded ☒ Welded ☐ Solvent Weld
☐ Cemented between strata
Describe access port

7. WATER LEVEL

Static water level 100 feet below land surface.
Flowing? ☐ Yes ☒ No G.P.M. flow
Artesian closed-in pressure p.s.i.
Controlled by: ☐ Valve ☐ Cap ☐ Plug
Temperature °F. Quality

8. WELL TEST DATA

☐ Pump ☐ Bailer ☐ Air ☐ Other

Discharge G.P.M.	Pumping Level	Hours Pumped
<u>12 gpm</u>		
<u>Est. Airlift</u>		

9. LITHOLOGIC LOG

Hole Diam.	Depth		Material	Water	
	From	To		Yes	No
<u>10</u>	<u>0</u>	<u>115</u>	<u>Clay, Brown, Dry</u>		<u>X</u>
<u>6</u>	<u>115</u>	<u>150</u>	<u>Quartz-like, Blueish, Dry</u>		<u>X</u>
<u>6</u>	<u>150</u>	<u>185</u>	<u>Quartz-like, Blueish, Fract.</u>	<u>X</u>	

605703

RECEIVED

SEP 24 1980

Department of Water Resources
Northern District Office


180' PVC Liner Installed
6" Drive Shoe Installed

10.

Work started 9/9/80 finished 9/10/80

6. LOCATION OF WELL

Sketch map location must agree with written location.



Subdivision Name
Lot No. Block No.

County Benewah

SE ¼ SW ¼ Sec. 34, T. 47 N/S, R. 2W E/W.

11. DRILLERS CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.
Ponderosa Drilling
Firm Name & Development, Inc. Firm No. 228
E. 6010 Broadway
Address Spokane, WA 99206 Date 9/12/80
Signed by (Firm Official) W. Scott Barratt
and
(Operator) Paul Hawkins

USE ADDITIONAL SHEETS IF NECESSARY -- FORWARD THE WHITE COPY TO THE DEPARTMENT