Form 238-7
7/94

RECEIVED
NOV 30 1995
NORTHERN REGION

POSTED

IDAHO DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORT

Use Typewriter or Ball Point Pen

1. DRILLING PERMIT NO. 91-95-N-11-000
Other IDWR No.

2. OWNER:
Name John Sines
Address 112 Riverdale Dr
City St. Maries State Id Zip 83861

3. LOCATION OF WELL by legal description:
Sketch map location must agree with written location.

N / W / E / S

Twp. 46 North ☒ or South ☐
Rge. 2 East ☐ or West ☒
Sec. 23, 1/4 SW (10 acres) 1/4 NE (40 acres) 1/4 (160 acres)
Gov't Lot ____ County Benewah
Address of Well Site 112 Riverdale Dr
City St Maries
(Give at least name of road + Distance to Road or Landmark)

Lt. ____ Blk. ____ Sub. Name ____

4. PROPOSED USE:
☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other

5. TYPE OF WORK
☒ New Well ☐ Modify or Repair ☐ Replacement ☐ Abandonment

6. DRILL METHOD
☐ Mud Rotary ☒ Air Rotary ☐ Cable ☐ Other

7. SEALING PROCEDURES

SEAL/FILTER PACK Material	From	To	AMOUNT Sacks or Pounds	METHOD
Bentonite	1	20	800 LB	Tremmie

Was drive shoe used? ☒ Y ☐ N Shoe Depth(s) 320
Was drive shoe seal tested? Y ☒ N ☐ How? Pounds

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
6	1	320	250	Steel	☒	☐	☒	☐
					☐	☐	☐	☐
					☐	☐	☐	☐

Length of Headpipe — Length of Tailpipe

9. PERFORATIONS/SCREENS
☐ Perforations Method
☐ Screens Screen Type

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
						☐	☐
						☐	☐
						☐	☐

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:
2 ft. below ground Artesian pressure — lb.
Depth flow encountered — ft. Describe access port or control devices:

SW NE 23 46N 2W

11. WELL TESTS:
☐ Pump ☐ Bailer ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
100+	By Air Lift		

Water Temp. cool Bottom hole temp. cool
Water Quality test or comments: None

12. LITHOLOGIC LOG: (Describe repairs or abandonment)

Bore Dia.	From	To	Remarks: Lithology, Water Quality & Temperature	Water Y	Water N
8	1	20	Hard Pan Brown		X
6	20	300	Gray Clay		X
6	300	320	Sand gravel	X	
			This well is gravel Packed up in the pipe From 320 To 290 3/4 By 1/2"		

Completed Depth 320 / 290' (Measurable)
Date: Started 11/8 Completed 11/10

13. DRILLER'S CERTIFICATION
I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name Precision Drilling Inc Firm No. 538
Firm Official [signature] Date 11/15/95
and
Supervisor or Operator [signature] Date 11/15/95
(Sign once if Firm Official & Operator)

FORWARD WHITE COPY TO WATER RESOURCES