

POSTED

STATE OF IDAHO
DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORTState law requires that this report be filed with the Director, Department of Water Resources
within 30 days after the completion or abandonment of the well.RECEIVED
OCT 26 1988
PH

1. WELL OWNER

Name Norman Bengland.
Address RT 1 # 93 Benewah.
Owner's Permit No. ST Maries Ida 83861
95-8815-100

7. WATER LEVEL

Department of Water Resources

Static water level 30 feet below land surface.
Flowing? ☐ Yes ☒ No G.P.M. flow _____
Artesian closed-in pressure _____ p.s.i.
Controlled by: ☐ Valve ☒ Cap ☐ Plug
Temperature cold °F. Quality clear
Describe artesian or temperature zones below.

2. NATURE OF WORK

- ☒
- New well
- ☐
- Deepened
- ☐
- Replacement
-
- ☐
- Abandoned (describe abandonment procedures such as materials, plug depths, etc. in lithologic log)

8. WELL TEST DATA

- ☐
- Pump
- ☐
- Bailer
- ☒
- Air
- ☐
- Other _____

Discharge G.P.M. Pumping Level Hours Pumped

8 Variable 1 hr

3. PROPOSED USE

- ☒
- Domestic
- ☐
- Irrigation
- ☐
- Test
- ☐
- Municipal
-
- ☐
- Industrial
- ☐
- Stock
- ☐
- Waste Disposal or Injection
-
- ☐
- Other _____ (specify type)

4. METHOD DRILLED

- ☒
- Rotary
- ☐
- Air
- ☐
- Hydraulic
- ☐
- Reverse rotary
-
- ☐
- Cable
- ☐
- Dug
- ☐
- Other _____

5. WELL CONSTRUCTION

Casing schedule: ☒ Steel ☐ Concrete ☐ Other _____

Thickness	Diameter	From	To
<u>1.250</u> inches	<u>6</u> inches	<u>2</u> feet	<u>18</u> feet
_____ inches	_____ inches	_____ feet	_____ feet
_____ inches	_____ inches	_____ feet	_____ feet
_____ inches	_____ inches	_____ feet	_____ feet

Was casing drive shoe used? ☒ Yes ☐ NoWas a packer or seal used? ☐ Yes ☒ NoPerforated? ☐ Yes ☒ NoHow perforated? ☐ Factory ☐ Knife ☐ Torch

Size of perforation _____ inches by _____ inches

Number	From	To
_____ perforations	_____ feet	_____ feet
_____ perforations	_____ feet	_____ feet
_____ perforations	_____ feet	_____ feet

Well screen installed? ☐ Yes ☒ No

Manufacturer's name _____

Type _____ Model No. _____

Diameter _____ Slot size _____ Set from _____ feet to _____ feet

Diameter _____ Slot size _____ Set from _____ feet to _____ feet

Gravel packed? ☐ Yes ☒ No ☐ Size of gravel _____

Placed from _____ feet to _____ feet

Surface seal depth 18 Material used in seal: ☐ Cement grout☒ Bentonite ☐ Puddling clay ☒ CatclaysSealing procedure used: ☐ Slurry pit ☐ Temp. surface casing☒ Overbore to seal depthMethod of joining casing: ☐ Threaded ☒ Welded ☐ Solvent

Weld

☐ Cemented between strata

Describe access port _____

6. LOCATION OF WELL

Sketch map location must agree with written location.

N				
W				E

Subdivision Name _____
Lot No. _____ Block No. _____

County BenewahNW 1/4 SE 1/4 Sec. 8, T. 45 N, R. 3 E/W.

10.

Work started 9/26/88 finished 9/27/88

11. DRILLERS CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name Common Development Firm No. 452Address P.O. Box 430 Date _____Signed by (Firm Official) John Common VP

and

(Operator) Robert F. Dugitz