

REPORT OF WELL DRILLER
State of Idaho

(0.1N3)

RECEIVED
JUN 20 1966

State law requires that this report shall be filed with the State Department of Reclamation Engineer within 30 days after completion or abandonment of the well.

WELL OWNER:

Name Frank Botts

Address St Marie Idaho

91-65-N-4

Owner's Permit No. not given

NATURE OF WORK (check): Replacement well ☐

New well ☒ Deepened ☐ Abandoned ☐

Water is to be used for: Domestic

METHOD OF CONSTRUCTION: Rotary ☐ Cable ☒

Dug ☐ Other ☐

(explain)

CASING SCHEDULE: Threaded ☐ Welded ☒

6 "Diam. from 0 ft. to 63 ft.

"Diam. from ft. to ft.

"Diam. from ft. to ft.

"Diam. from ft. to ft.

Thickness of casing: .250 Material:

Steel ☒ concrete ☐ wood ☐ other ☐

(explain)

PERFORATED? Yes ☒ No ☐ Type of

perforator used: Cutting tool

Size of perforations: 1/16 " by 2 "

perforations from 0 ft. to 10 ft.

perforations from ft. to ft.

perforations from ft. to ft.

perforations from ft. to ft.

WAS SCREEN INSTALLED? Yes ☐ No ☒

Manufacturer's name

Type Model No.

Diam. Slot size Set from ft. to ft.

Diam. Slot size Set from ft. to ft.

CONSTRUCTION: Well gravel packed? Yes ☐

No. ☒ size of gravel Gravel

placed from ft. to ft. Surface seal

provided? Yes ☐ No ☒ To what depth?

 ft. Material used in seal:

Did any strata contain unusable water? Yes ☐

No. ☒ Type of water:

Depth of strata ft. Method of sealing

strata off:

Surface casing used? Yes ☐ No. ☒

Cemented in place? Yes ☐ No ☐

Locate well in section

X			

LOCATION OF WELL: County Benedict

NW 1/4 NW 1/4 Sec. 16 T. 46 N. 8 R. 2 E. W

Size of drilled hole: 6 " Total

depth of well: 63 ft Standing water

level below ground: 48 ft Temp.

Fahr. ° Test delivery: 10 gpm

or cfs Pump? ☐ Bail ☒

Size of pump and motor used to make test:

Length of time of test: 3 Hrs. Min.

Drawdown: None ft. Artesian pressure: ft.

above land surface Give flow cfs

or gpm. Shutoff pressure:

Controlled by: Valve ☐ Cap ☐ Plug ☐

No control ☐ Does well leak around casing?

Yes ☐ No ☐

DEPTH MATERIAL WATER

FROM TO YES OR NO

FEET FEET

0 18 Brown Clay and sand no

18 25 Broken Basalt and Clay no

25 63 Broken Basalt yes

Use other side for additional remarks

WSS