

NORTHERN REGION
IDWR

HOSTED

IDAHO DEPARTMENT OF WATER RESOURCES WELL DRILLER'S REPORT

Use Typewriter
or
Ball Point Pen

1. DRILLING PERMIT NO. 91-95-N-10 - 070


Other IDWR No.

2. OWNER:

Name ORA Faye Collier
Address 1478 BRYAN AVE
City SAN JOSE State CA Zip 95118

3. LOCATION OF WELL by legal description:

Sketch map location must agree with written location.

N

 W E S
 Twp. 46 North ☒ or South ☐
 Rge. 2 East ☐ or West ☒
 Sec. 14 1/4 1/4 1/4 1/4
 Gov't Lot _____ County BENNEHAN 10 acres 40 acres 160 acres
 Address of Well Site 1-mile up St. Joe
ROAD City ST. MARIES
 (Give at least name of road + Distance to Road or Landmark)

Lt. _____ Blk. _____ Sub. Name _____

4. PROPOSED USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other

5. TYPE OF WORK

☒ New Well ☐ Modify or Repair ☐ Replacement ☐ Abandonment

6. DRILL METHOD

☐ Mud Rotary ☒ Air Rotary ☐ Cable ☐ Other

7. SEALING PROCEDURES

SEAL/FILTER PACK			AMOUNT	METHOD
Material	From	To	Sacks or Pounds	
Bentonite	0	42	1500	West Shurey bar

Was drive shoe used? ☒ Y ☐ N Shoe Depth(s) 68.5
Was drive shoe seal tested? Y ☒ N ☐ How? Air Pressure

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
6"	+1.5	68.5	250	steel	☒	☐	☒	☐
					☐	☐	☐	☐
					☐	☐	☐	☐

Length of Headpipe _____ Length of Tailpipe _____

9. PERFORATIONS/SCREENS

☒ Perforations Method Torch cut 1/4 holes
☐ Screens Screen Type

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
48.5	68.5	1 1/4"	60	1 1/4"	Steel	☒	☐
						☐	☐
						☐	☐

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:

20 ft. below ground Artesian pressure _____ lb.
Depth flow encountered 50-75 ft. Describe access port or
control devices: CAP

SWN(11) 14 410N 24)

11. WELL TESTS:

☐ Pump ☐ Bailer ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
100 +		68'	2 hrs

Water Temp. Cold Bottom hole temp.

Water Quality test or comments: CLEAR + NO OBDS

12. LITHOLOGIC LOG: (Describe repairs or abandonment)

[illegible]

Completed Depth 80 (Measurable)

Date: Started Aug 31, 1995 Completed Sept 1, 1995

13. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name ALL-WAYS Drilling, Inc Firm No. 510

Firm Official Stanley K Wolfe Date 9/7/95

Supervisor or Operator _____ Date _____

(Sign once if Firm Official & Operator)

FORWARD WHITE COPY TO WATER RESOURCES