Form 238-7
6/89

STATE OF IDAHO
DEPARTMENT OF WATER RESOURCES

USE TYPEWRITER OR BALLPOINT PEN

WELL DRILLER'S REPORT

State law requires that this report be filed with the Director, Department of Water Resources within 30 days after the completion or abandonment of the well.

RECEIVED
DEC 2 8 1990
NORTHERN REGION
IDWR

1. WELL OWNER

Name Peter & Mary Nemeth

Address St. Maries, Idaho

Owner's Permit No. 91-90-N-7

2. NATURE OF WORK

☒ New well ☐ Deepened ☐ Replacement
☐ Well diameter increase
☐ Abandoned (describe abandonment procedures such as materials, plug depths, etc. in lithologic log)

3. PROPOSED USE

☐ Domestic ☐ Irrigation ☐ Test ☐ Municipal
☐ Industrial ☐ Stock ☐ Waste Disposal or Injection
☒ Other R.V. Park (specify type)

4. METHOD DRILLED

☒ Rotary ☒ Air ☐ Hydraulic ☐ Reverse rotary
☐ Cable ☐ Dug ☐ Other

5. WELL CONSTRUCTION

Casing schedule: ☒ Steel ☐ Concrete ☒ Other PVC

Thickness		Diameter		From		To	
.250	inches	6"	inches +	1½	feet	53	feet
	inches		inches		feet		feet
160 PSI	inches	4"	inches	40	feet	201	feet
PVC	inches		inches		feet		feet

Was casing drive shoe used? ☒ Yes ☐ No
Was a packer or seal used? ☐ Yes ☐ No
Perforated? ☐ Yes ☐ No
How perforated? ☐ Factory ☐ Knife ☒ Torch ☐ Gun
Size of perforation ⅛ inches by 6" inches

Number		From		To	
8	perforations	48	feet	52	feet
	perforations		feet		feet
	perforations		feet		feet

Well screen installed? ☐ Yes ☒ No
Manufacturer's name
Type Model No.
Diameter Slot size Set from feet to feet
Diameter Slot size Set from feet to feet
Gravel packed? ☐ Yes ☐ No ☐ Size of gravel
Placed from feet to feet
Surface seal depth 18+ Material used in seal: ☐ Cement grout
☒ Bentonite ☐ Puddling clay ☐
Sealing procedure used: ☐ Slurry pit ☒ Temp. surface casing ☒ Overbore to seal depth
Method of joining casing: ☐ Threaded ☒ Welded ☒ Solvent Weld ☐ Cemented between strata
Describe access port

6. LOCATION OF WELL

Sketch map location must agree with written location.

N / W / E / S

Subdivision Name
Lot No. Block No.

County Benewah

SE ¼ SE ¼ Sec. 12, T. 46 N ☒ S ☐ R. 2 E ☐ W ☒

RECEIVED
DEC 27 1991

7. WATER LEVEL

Static water level ukn feet below land surface
Flowing? ☐ Yes ☐ No G.P.M. flow
Artesian closed-in pressure p.s.i.
Controlled by: ☐ Valve ☐ Cap ☐ Plug
Temperature °F. Quality
Describe artesian or temperature zones below.

8. WELL TEST DATA

☐ Pump ☐ Bailer ☒ Air ☐ Other

Discharge G.P.M.	Pumping Level	Hours Pumped
12-15 GPM		

9. LITHOLOGIC LOG

Bore Diam.	Depth From	Depth To	Material	Water Yes	Water No
8"	0	50	Shale Gravel	X	
"	50	53	Shale		
6"	53	120	Shale soft	X	
"	120	178	Shale Blue	X	
"	178	196	Shale Hard		
"	196	201	Shale softer		

RECEIVED
JAN 03 1991
Department of Water Resources

ORIGINAL

10.

Work started 10-9-90 finished 10-10-90

11. DRILLERS CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name AQUA DRILLING & EXPLORATION INC Firm No. 163
Address PO BOX 225 Coeur d'Alene, ID 83814 Date 10-10-90
Signed by (Firm Official) Scott N. Braun Pres.
and (Operator) Scott N Braun/President Scott N. Braun

USE ADDITIONAL SHEETS IF NECESSARY — FORWARD THE WHITE COPY TO THE DEPARTMENT