

RECEIVED

Form 238-7
3/95

JUL 07 1998

IDAHO DEPARTMENT OF WATER RESOURCES

WELL DRILLER'S REPORT

Use Typewriter or Ballpoint Pen

77490

NORTHERN REGION

1. DRILLER'S PERMIT NO.

Other IDWR No. 91-98 N-0005-

2. OWNER:

Name Rick & Nikki Huddleston
Address HR 3 Box 90
City St. Maries State Id Zip 83861

POSTED

3. LOCATION OF WELL by legal description:

Sketch map location must agree with written location.

N
W
E
S

Twp. 4E North ☒ or South ☐
Rge. 1 East ☒ or West ☐
Sec. 20 1/4 1/4 1/4 1/4
Gov't Lot 12 County Beneish
Lat: : : Long: : :
Address of Well Site St. Joe City & Huddleston Rd City St. Joe city
(Give at least name of road + Distance to Road or Landmark)

Lt. Blk. Sub. Name

4. USE:

- ☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other

5. TYPE OF WORK check all that apply (Replacement etc.)

- ☒ New Well ☐ Modify ☐ Abandonment ☐ Other

6. DRILL METHOD

- ☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other

7. SEALING PROCEDURES

SEAL/FILTER PACK			AMOUNT	METHOD
Material	From	To	Sacks or Pounds	
Bentonite	0	38	450#	Pour dry

Was drive shoe used? ☒ Y ☐ N Shoe Depth(s) 38'
Was drive shoe seal tested? ☒ Y ☐ N How? Air

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
6"	+2	38	.250	Steel	☒	☐	☒	☐
4"	5	155	110	PVC	☐	☒	☐	☐

Length of Headpipe N/A Length of Tailpipe N/A

9. PERFORATIONS/SCREENS

- ☒ Perforations Method Drill
☐ Screens Screen Type

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
95'	155	1/4"	100	4"	PVC	☐	☒

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:

42 ft. below ground Artesian pressure N/A lb.
Depth flow encountered 122 ft. Describe access port or control devices: Well cap

46N 1E S20

FORWARD WHITE COPY TO WATER RESOURCES

Office Use Only
Inspected by RFD
Twp 46N Rge 1E Sec 20
1/4 NE 1/4 SW 1/4
Lat: : : Long: : :

11. WELL TESTS:

- ☐ Pump ☐ Bailer ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
8			1 hr

Water Temp. Cold Bottom hole temp. Cold
Water Quality test or comments: Clear

Depth first Water Encountered 82

12. LITHOLOGIC LOG: (Describe repairs or abandonment)

Bore Dia.	From	To	Remarks: Lithology, Water Quality & Temperature	Y	N
8"	0	12	Sand brown		☒
8"	12	18	Gravels (large)		☒
8"	18	38	Shale gray soft		☒
6"	38	42	Shale gray med		☒
6"	42	120	Shale brown soft 82'	☒	
6"	120	175	Shale gray broken 3 gpm 122' 5+ gpm	☒	

Completed Depth 155 (Measurable)
Date: Started 6-12-98 Completed 6-16-98

13. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name Always Drilling Firm No. 510
Firm Official Steve & wife Date 6-16-98
and
Supervisor or Operator Witherell Date 6-16-98
(Sign once if Firm Official & Operator)