

DISTRICT
 COUNTY
 TOWNSHIP
 RANGE
 SECTION
 SUBSECTION
 QUARTER
 CORNER
 BEARING
 DISTANCE
 AREA
 COMMENTS

RECEIVED
 JAN 20 1969
 ENT'D

REPORT OF WELL DRILLER
 State of Idaho

Department of Reclamation

State law requires that this report shall be filed with the State Reclamation Engineer within 30 days after completion or abandonment of the well.

WELL OWNER:
 Name William L. Mason
 Address Cataldo Ida
94-68-N-10

Owner's Permit No. _____
 NATURE OF WORK (check): Replacement well ☐
 New well ☒ Deepened ☐ Abandoned ☐
 Water is to be used for: Home
 METHOD OF CONSTRUCTION: Rotary ☒ Cable ☐
 Dug ☐ Other _____ (explain)

CASING SCHEDULE: Threaded _____ Welded ☒
6 "Diam. from 0 ft. to 73' ft.
 "Diam. from _____ ft. to _____ ft.
 "Diam. from _____ ft. to _____ ft.
 "Diam. from _____ ft. to _____ ft.
 Thickness of casing: 250 Material:
 Steel ☒ concrete ☐ wood ☐ other ☐

(explain)
 PERFORATED? Yes ☐ No ☒ Type of
 perforator used: _____


Size of perforations: _____ " by _____ "
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.
 _____ perforations from _____ ft. to _____ ft.

WAS SCREEN INSTALLED? Yes ☐ No ☒
 Manufacturer's name _____
 Type _____ Model No. _____
 Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.
 Diam. _____ Slot size _____ Set from _____ ft. to _____ ft.

CONSTRUCTION: Well gravel packed? Yes ☐
 No ☒ size of gravel _____ Gravel
 placed from _____ ft. to _____ ft. Surface seal
 provided? Yes ☐ No ☐ To what depth?
 _____ ft. Material used in seal: _____

Did any strata contain unusable water? Yes ☐
 No ☒ Type of water: _____
 Depth of strata _____ ft. Method of sealing
 strata off: _____

Surface casing used? Yes ☐ No ☒
 Cemented in place? Yes ☐ No ☐



LOCATION OF WELL: County Kootenai
NE 1/4 SE 1/4 Sec. 15 T. 49 N. R. 1 W

Size of drilled hole: 6 " Total
 depth of well: 150' Standing water
 level below ground: 60' Temp.
 Fahr. _____ ° Test delivery: 14 gpm
 or _____ cfs Pump? ☐ Bail ☐
 Size of pump and motor used to make test:
Flow Checked with Weir
 Length of time of test: 2 Hrs. 30 Min.
 Drawdown: _____ ft. Artesian pressure: ft.
 above land surface _____ Give flow _____ cfs
 or _____ gpm. Shutoff pressure:
 Controlled by: Valve ☐ Cap ☐ Plug ☐
 No control ☐ Does well leak around casing?
 Yes ☐ No ☒

DEPTH FROM	TO	MATERIAL	WATER YES OR NO
FEET	FEET		
0	3	Top Soil & Gravel	No
3	70	Clay	No
70	118	Cemented Gravel	No
118	150	Black Argillite	Yes

Work started: Sept 18, 1968
 Work finished: Sept 19, 1968
 Well Driller's Statement: This well was
 drilled under my supervision and this report
 is true to the best of my knowledge.
 Name: Bob Wellbrock
 Address: 211 W. 2nd St.
 Signed by: [Signature]
 License No. 105 Date: Jan 15 1969

EA Holmen Drilling Co

Use other side for additional remarks
~~N 1/2 of S 1/4 E 1/4 of S 1/4 E 1/4 of Sec 15 R 49 W 1/4~~

11565