

JUN 18 2011

Inspected by _____
Twp _____ Rge _____ Sec _____
1/4 1/4 1/4
Lat _____ : Long: _____ : _____

Drilling Permit No. North
Other IDWR No. 768 563

sketch map location must agree with written location

Twp. 49 ☒ North or ☐ South
Rge. 04 ☐ East or ☒ West
Sec. 4 SE 1/4 NW 1/4 1/4

Lat: : : Long: : :

Address of Well Site Mica Flats Area
City Coeur d' Alene

(Give at least name of road + Distance to Road or Landmark)

Lt. Blk. _____ Sub. Name _____

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other _____

☒ New Well ☐ Modify ☐ Abandonment ☐ Other☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other

SEAL/FILTER PACK			AMOUNT	METHOD
Material	From	To	Sacks or Pounds	
BENTONITE	0	18	10 bags	Over bore

Was drive shoe used? ☒ Y ☐ N Shoe Depth(s) 46'

Was drive shoe seal tested? ☐ Y ☐ N How?

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
					☐	☐	☐	☐
6	+2	-124	250	Steel	☒	☐	☒	☐
8	+1	46	250	Steel	☒	☐	☒	☐

Length of Headpipe _____ Length of Tailpipe _____

9. PERFORATIONS/SCREENS

☐ Perforations Method _____
☒ Screens Screen Type SS

From	To	Slot Size	Number	Diameter	Material
-128	-138	.20		5	SS
-125	-130	.20		5	Stainless Steel

Casing ☐

☐

Liner ☒

☒

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:

40 ft. below ground Artesian pressure _____ lb.
Depth flow encountered _____ ft. Describe access port or control devices: _____

49N 4W 4

☐ Pump ☐ Bailer ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
30			

Water Quality test or comments: Clear

Depth first Water encountered 40

12. LITHOLOGIC LOG: (Describe repairs or abandonment)

[illegible]

13. DRILLER'S CERTIFICATION

1/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name H2O WellService, Inc. Firm No. 448

Firm Official Theresa K. Smith Date 7-12-01

and *and to 7/6/61*

Supervisor or Operator [Signature] Date 7/2/01
(Sign Once if Firm Official and Operator)

Jim McLeslie

JUN 18 2014