

IDAHO DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORT

092336

RECEIVED
MAR 04 1994
Use Typewriter or Ball Point Pen
IDWR / NORTH1. DRILLING PERMIT NO. 95-93-11-217-000
Other IDWR No. _____

2. OWNER:

Name Joseph McGinn
Address S. 3505 Alament
City Spokane State WA Zip 99223

3. LOCATION OF WELL by legal description:

Sketch map location must agree with written location.

N			
S			

W 50 North ☒ or South ☐
E 4 East ☐ or West ☒
Sec. 8 1/4 SW 1/4 SW 1/4 NW 1/4
Gov't Lot _____ County Kootenai

Address of Well Site 6283 Amber Drive

(Give at least Direction + Distance to Road or Landmark)

Lot No. 18 Block No. _____ Subd. Name Hawke Island Addition

4. PROPOSED USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other _____

5. TYPE OF WORK

☒ New Well ☐ Modify or Repair ☐ Replacement ☐ Abandonment

6. DRILL METHOD

☐ Mud Rotary ☒ Air Rotary ☐ Cable ☐ Other _____

7. SEALING PROCEDURES

SEAL/FILTER PACK			AMOUNT		METHOD
Material	From	To	Sacks or Pounds		
<u>Bentonite</u>	<u>40</u>	<u>19</u>			
<u>6"-8" Packer</u>	<u>40</u>				

Was drive shoe seal tested? ☒ Yes ☐ No How? Air Pressure

8. CASING/LINER:

Diameter	From	To	Gauge	Casting	Liner	Steel	Plastic	Welded	Threaded
<u>6</u>	<u>+1</u>	<u>172</u>	<u>250</u>	<u>St.</u>		☒	☐	☒	☐

Final location of shoes 172'

Top Packer or Headpipe _____ Bottom Tailpipe _____

9. PERFORATIONS/SCREENS NONE
☐ Perforations Method _____
☐ Screens Type _____ Material _____

From	To	Slot Size	Number	Diameter	Tail/Pipe Size	Casting	Liner
						☐	☐
						☐	☐
						☐	☐

SW34 NW 8 SON 4W

10. WELL TESTS:

☐ Pump ☐ Bailor ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Depth	Time
<u>60</u>			

Temperature of water 60 Was a water analysis done? Yes ☐ No ☐

By whom? _____

Water Quality (odor, etc.) Good No Smell

Bottom Hole Temperature _____

11. STATIC WATER LEVEL:

120 ft. below surface Depth artesian flow found _____Artesian pressure _____ lb. Describe access point Batted well cap

Describe Controlling Devices: _____

12. LITHOLOGIC LOG: (Describe repairs or abandonment)

Bore Dia.	From	To	Remarks: Lithology, Water Quality & Temperature	GPM	SWL
<u>8</u>	<u>0</u>	<u>172</u>			
<u>6</u>	<u>172</u>	<u>175</u>			
			<u>0 12 Loose sandy clay & gravel</u>		
			<u>12 157 Clay Gravel & Boulders</u>		
			<u>157 175 Small Gravel & coarse sand</u>		
			<u>Hit water 172'</u>		

13. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name AQUA DRILLING & EXPLORATION INC. Firm No. 163Firm Official Scott M. Braun Date _____and Supervisor or Operator Wayne Miller Date 10-27-93

(Sign once if Firm Official & Operator)

FORWARD WHITE COPY TO WATER RESOURCES

SCANNED

AUG 14 2014