




INVOICE

Nº 7935

INVOICE DATE June 17, 1997	ORDER NO.
SHIP TO	
Residence	

Post Office Box 1690, Hayden Lake, ID 83835
(208) 772-3230 • (800) 682-9641 • Fax (208) 772-7229

SOLD TO: Gary Johnson
5180 South Hwy 97
Harrison ID 83833

PHONE # 208-667-6801

INSTALLATION/SERVICE DATE		SHIPPED VIA	F.O.B. POINT	TERMS	
June 12, 1997		Installed	Customers well site	Payment Due	
QTY.	UNIT	DESCRIPTION		UNIT PRICE	TOTAL
1	ea.	3/4 HP, 7 GPM, Jacuzzi pump/motor/control.		\$598.00	\$598.00
1	ea.	5 Year MFG. Pump and motor warranty # 115531		\$50.00	\$50.00
137	lf.	1" Galvanized Drop pipe.		\$1.40	\$191.00
2	ea.	1" Brass check valves.		\$15.00	\$30.00
145	lf.	# 10/4 TW Submersible wire.		\$0.75	\$109.00
1	ea.	Motor Splice and tape.		\$25.00	\$25.00
1	ea.	1" Pitless adapter.		\$45.00	\$45.00
1	ea.	6" Cast Iron well cap and conduit.		\$55.00	\$55.00
1	ls.	Labor to install well pump to "top of well".		\$275.00	\$275.00
1	ls.	Plumbing @ well.		\$45.00	\$45.00
1	ea.	4' Bury yard hydrant and related fittings @ well.		\$45.00	\$45.00
125	lf.	# 12/2 UF wire with ground.		\$0.30	\$37.00
115	lf.	# 10/3 UF wire with ground.		\$0.75	\$86.00
1	ea.	81 Gallon pressure tank, tank assy, and plumbing under home.		\$485.00	\$485.00
1	ls.	4 hour well test, and water quality and bacteria samples.		\$250.00	\$250.00
1	ls.	Plumbing @ water line tie in.		\$14.00	\$14.00
1	ls.	Misc. Electrical, and electrical permit # C 335580		\$115.00	\$115.00
1	ls.	Labor to install "balance of system".		\$250.00	\$250.00
				TOTAL DUE	\$2,705.00

PAID

CHECK NO.

2053

AMOUNT

2705.00

DATE

6/12/97

PAID		
CHECK NO. <u>2053</u>	AMOUNT <u>\$2,705.00</u>	DATE <u>6/17/97</u>



WELL TEST

Customer: Gary Johnson

Address: 5180 S. Highway 97
Harrison, ID 83833

Job Location: Residence

Phone: 208-667-6801

WELL DATA

Total Depth: 167'

Test Pump Used: 3/4 HP, 7 GPM

Static Water Level: 40'

Pump Setting: 137'

Driller Tested: @ 7-7.5 GPM

Date of Test: 6-16-97

TIME	FLOW RATE Gallons Per Minute	PRESSURE Per Square Inch		STATIC LEVEL
11:00	13.00	0.00	Color	40'
11:15	13.00	0.00	Color	Unknown
11:30	11.50	0.00	Color	Unknown
11:45	8.00	0.00	Color	Unknown
12:00	8.00	0.00	Clear	Unknown
12:15	7.70	0.00	Clear	Unknown
12:30	7.70	0.00	Clear	Unknown
12:45	7.70	0.00	Clear	Unknown
1:00	7.70	0.00	Clear	Unknown
1:15	7.70	0.00	Clear	Unknown
1:30	7.70	0.00	Clear	Unknown
1:45	7.70	0.00	Clear	Unknown
2:00	7.70	0.00	Clear	Unknown
2:15	7.70	0.00	Clear	Unknown
2:30	7.70	0.00	Clear	Unknown
2:45	7.70	0.00	Clear	Unknown
3:00	7.70	0.00	Clear	Unknown

Test Summary: This well produced an average of 8.58 gallons over the 4-hr test period.

Certified By: 

Richard A. Agueros, President
UNITED PUMP COMPANY