

WELL DRILLER'S REPORT

RECEIVED

Office Use Only			
Inspected by			
Twp	Rge	Sec	
1/4	1/4	1/4	
Lat	:	Long	:

1. WELL TAG NO. D0013663 SEP 19 2000

Drilling Permit No:

Other IDWR No.

766469 IDWR/North

2. OWNER

Well Number:

Name Dale Volkerts


102

Address 11945 Via Zapata

City El Cajon State CA Zip 92019

3. LOCATION OF WELL by legal description

sketch map location must agree with written location



Twp. 49 North or South

Rge. 02 East or West

Sec. 29 1/4 NW 1/4 SW 1/4

Gov't Lot County SHOSHONE

Lat: : Long: :

Address of Well Site

City Kingston

(Give at least name of road + Distance to Road or Landmark)

Lt. Blk. Sub. Name

4. USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation

☐ Thermal ☐ Injection ☐ Other

5. TYPE OF WORK check all that apply (Replacement, etc.)

☒ New Well ☐ Modify ☐ Abandonment ☐ Other

6. DRILL METHOD

☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other

7. SEALING PROCEDURES

SEAL/FILTER PACK			AMOUNT	METHOD
Material	From	To	Sacks or Pounds	
Well seal				
BENTONITE	0	30	10 bags	overbore

Was drive shoe used? ☒ Y ☐ N Shoe Depth(s) 310

Was drive shoe seal tested? ☐ Y ☐ N How?

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
6	+2	-310	.250	steel	☒	☐	☒	☐
5	-300	-340	.250	steel	☒	☐	☒	☐

Length of Headpipe Length of Tailpipe

9. PERFORATIONS/SCREENS

☒ Perforations Method torch

☐ Screens Screen Type

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
-320	-340	1/4x6	64	5	steel	☒	☐

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:

315 ft. below ground Artesian pressure lb.

Depth flow encountered ft. Describe access port or control devices:

11. WELL TESTS:

☐ Pump ☐ Bailor ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
2-3		340	1 hour

Water Temp. cold Bottom Hole Temp. cold

Water Quality test or comments:

Depth first Water encountered 320

12. LITHOLOGIC LOG:(Describe repairs or abandonment)

				Water	
Bore Diam	From	To	Remarks: Lithology, Water Quality, Temperature	Y	N
8	0	31	Clayish soil w/gravel	☐	☒
8	31	48	Clay redish tan	☐	☒
8	48	141	Clay brown w/gravel	☐	☒
8	141	175	Clay redish tan	☐	☒
8	175	268	Gravel w/clay yellowish	☐	☒
8	268	340	Gravel w/clay seams w/H2O	☒	☐

Completed Depth 340 (Measurable)
Date: Started 9/6/00 Completed 9/12/00

13. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name H2O Well Service, Inc. Firm No. 448

Firm Official Date 9-15-00

and Supervisor or Operator Date 9-15-00

(Sign Once as Firm Official and Operator)

Louie Hanner

49N 2E 29