

POSTED

2. OWNER: Terry Waddell
Name
Address 2315 Cromwell Drive
City St. Maries State ID Zip 83861

Sketch map location must agree with written location.

N

		X

 Twp. 46 North ☒ or South ☐
 Rge. 3 East ☐ or West ☒
 Sec. 14 1/4 1/4 1/4 1/4
 Gov't Lot _____ County Beneviah 10 acres 40 acres 160 acres
 Lat. : : Long. : :
 S
 Address of Well Site Beneviah Lake
 Rd. 1/2 mile on right top of Hill City St. Marias
 (Give at least name of road + Distance to Road or landmark)

[illegible]

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other

☒ New Well ☐ Modify ☐ Abandonment ☐ Other _____

☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other

SEAL/FILTER PACK			AMOUNT	METHOD
Material	From	To	Sacks or Pounds	
Bentonite	0	30	75A	Pour Around Pipe

Was drive shoe used? ☒ Y ☐ N Shoe Depth(s) 91
Was drive shoe seal tested? ☒ Y ☐ N How? air

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
6"	+2	-91	250	Steel	☒	☐	☒	☐
4"	-5	200	160	PVC	☐	☒	☐	☐
					☐	☐	☐	☐

Length of Headpipe _____ Length of Tailpipe _____

Perforation Method Drill
Screens Screen Type

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
-160	-180	1"	14	4"	PVC	☐	☒
						☐	☐
						☐	☐

83' ft. below ground Artesian pressure _____ lb.
Depth flow encountered 137 ft. Describe access port or
control devices: Well cap

☐ Pump ☐ Bailer ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
25 gpm.	Air lift	from	200'

Water Temp. 52° Bottom hole temp. _____

Water Quality test or comments: Clear no odor

Depth first Water Encounter **137**

12. LITHOLOGIC LOG: (Describe repairs or abandonment) Water

[illegible]

Completed Depth 200 (Measurable)
Date: Started 10-8-01 Completed 10-9-01

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name All-Way Drilling Inc. Firm No. 510

Firm Official Frank A. Wolf Date 10-24-01

and

Driller or Operator Alvin Carris Date 10-24-01

(Sign once if Firm Official & Operator)

FORWARD WHITE COPY TO WATER RESOURCES