

IDAHO DEPARTMENT OF WATER RESOURCES WELL DRILLER'S REPORT

Office Use Only		
Inspected by _____		
Twp _____	Rge _____	Sec _____
1/4 _____	1/4 _____	1/4 _____
Lat : : _____	Long: : : _____	

1. WELL TAG NO. D0060884

DRILLING PERMIT N 812843
Other IDWR No _____

2. OWNER:

Name Deborah Desalliers
Address 5331 Breckenridge ave
City Banning State CA Zip 92220

3. LOCATION OF WELL by legal description:

N		Twp <u>49N</u>	North ☒ or South ☐
Rge <u>04W</u>		East ☐ or West ☒	
Sec <u>29</u>		1/4 NE 1/4 SW 1/4	
Gov't Lot _____		County <u>Kootenai</u>	
Lat <u>47:38:54</u>		Long <u>116:51:46</u>	

Address of Well Site: (see next line)
couger gulch rd first drive past grange City cda
Lot _____ Blk _____ Sub. Name (see next line)

4. USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other _____

5. TYPE OF WORK check all that apply (Replacement etc.)

☒ New Well ☐ Modify ☐ Abandonment ☐ Other _____

6. DRILL METHOD

☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other _____

7. SEALING PROCEDURES

SEAL/FILTER PACK			Amount	Method
Material	From	To	Sacks/Lbs	
bentonite	0	-39	19 sacks	dry poor

Drive Shoe Used? ☒ Y ☐ N Shoe Depth(s) 39
Drive Shoe Seal Tested? ☐ Y ☒ N How? _____

8. CASING/LINER

Diam	From	To	Gauge	Material	Casng	Liner	Weld	Thrded
6	+1	39	0.250	steel	☒	☐	☒	☐
4	-10	240	0.200	pvc	☐	☒	☐	☐
					☐	☐	☐	☐

Length Headpipe n/a Length Tailpipe n/a

9. PERFORATIONS/SCREENS

☒ Perforations? Method drill
☐ Screens? Screen Type _____

From	To	Slot	Nmbr	Diam	Material	Casng	Liner
180	280	3/8	500	3/8	pvc	☐	☒
						☐	☐
						☐	☐

10. STATIC WATER LEVEL or ARTESIAN PRESSURE

-20 ft. below ground. Artesian pressure 0 lb.
Depth flow encountered 160 ft. Describe access port or control devices: cap

11. WELL TESTS:

☐ Pump ☐ Bailer ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pump Level	Time
30 gpm	n/a	240	1hr

Water Temp. _____ cpd Bottom hole temp. cold
Water Quality test or comments: (below) Depth first Water Encountered 160
clear

12. LITHOLOGIC LOG (Describe repairs or abandonment)

Bore Diam	From	To	Remarks: Lithology, Water Quality and Temperature	Water	
				Y	N
10	0	2	top soil	☐	☒
10	2	39	dec granit	☐	☒
6	39	165	dec granit soft 5 gpm 160	☒	☐
6	165	240	med firm black granit 25 gpm 230	☒	☐

RECEIVED

APR 19 2012

IDWR / NORTH

Completed Dept 240 (Measurable)
Date: Started 1/7/2012 Completed 1/7/2012

13. DRILLERS CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name United Drilling Inc. Firm No 414
Firm Official Timothy R. Volking Date 2/7/2012
Supervisor or Operator Timothy R. Volking Date 2/7/2012

49N 04W 29

95

29

Domestic
Use



NESW

50N04W

Well



NWSE

SESW

SWSE