

IDAHO DEPARTMENT OF WATER RESOURCES WELL DRILLER'S REPORT

Location Corrected by IDWR To:
T49N R02E Sec. 8 NENESE
By: mciscell 2013-10-18

1. WELL TAG NO. D0058068

DRILLING PERMIT N

Other IDWR No

2. OWNER:

Name **Roy Nickerson**

Address P O Box 519

City Smelterville

State ID

Zip 83868

3. LOCATION OF WELL by legal description:

N		Twp	49N	North	☒ or	South	☐
W		Rge	02E	East	☐ or	West	☒
E		Sec	08	1/4 NW 1/4 NE 1/4			
S		Gov't Lot	County Shoshone				
		Lat	47:36:48	Long	116:13:40		

Address of Well Site: (see next line)

first drive on right past hunysukle dridge

City Kingston

Lot

Blk

Sub. Name (see next line)

4. USE:

- ☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other

5. TYPE OF WORK check all that apply (Replacement etc.)

- ☒ New Well ☐ Modify ☐ Abandonment ☐ Other

6. DRILL METHOD

- ☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other

7. SEALING PROCEDURES

SEAL/FILTER PACK			Amount	Method
Material	From	To	Sacks/Lbs	
bentonite	0	40	22 sacks	dry poor

Drive Shoe Used? ☒ Y ☐ N Shoe Depth(s) 100

Drive Shoe Seal Tested? ☐ Y ☒ N How?

8. CASING/LINER

Diam	From	To	Gauge	Material	Casng	Liner	Weld	Thrded
6	+2	100	0.250	steel	☒	☐	☒	☐
					☐	☐	☐	☐
					☐	☐	☐	☐

Length Headpipe n/a Length Tailpipe n/a

9. PERFORATIONS/SCREENS

☐ Perforations? Method

☐ Screens? Screen Type n/a

From	To	Slot	Nmbr	Diam	Material	Casng	Liner
						☐	☐
						☐	☐
						☐	☐

10. STATIC WATER LEVEL or ARTESIAN PRESSURE

-42 ft. below ground. Artesian pressure 0 lb.

Depth flow encountered 140 ft. Describe access port or

control devices: cap welded

11. WELL TESTS:

- ☐ Pump ☐ Bailer ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pump Level	Time
15 gpm	n/a	200	2hrs

Water Temp. cold Bottom hole temp. cold

Water Quality test or comments: (below) Depth first Water Encountered 140 clear

12. LITHOLOGIC LOG (Describe repairs or abandonment)

Bore Diam	From	To	Remarks: Lithology, Water Quality and Temperature	Water	
				Y	N
12	0	15	gravel clay mix	☐	☒
12	15	40	clay brown	☐	☒
8	40	82	clay brown	☐	☒
8	82	100	shale brown	☐	☒
6	100	139	shale brown	☐	☒
6	139	157	shale gray 5 gpm 139	☒	☐
6	157	200	shale gray 10 gpm 185	☒	☐

RECEIVED

NOV 12 2014

RECEIVED IDWR/NORTHERN

MAY 11 2010

IDWR/North



SCANNED

MAY 12 2010

Completed Dept 200 (Measurable)
Date: Started 5/5/2010 Completed 5/5/2010

13. DRILLERS CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name United Drilling Inc.

Firm No 414

Firm Official and

Timothy R. Volking

Date 5/7/2010

Supervisor or Operator Timothy R. Volking

Date 5/7/2010

SCANNED

NOV 19 2014