

WELL DRILLER'S REPORT

Office Use Only			
Inspected by			
Twp	Rge	Sec	
1/4	1/4	1/4	
Lat	:	:	Long
:	:	:	:

1. WELL TAG NO. D0017365

Drilling Permit No:

Other IDWR No.

2. OWNER


Name Bicky Buell & Dale Pierce

Address P.O. Box 349

City Plummer State ID Zip 83851

3. LOCATION OF WELL by legal description

sketch map location must agree with written location

Twp. 46 ☒ North or ☐ SouthRge. 02 ☐ East or ☒ West

E Sec. 19 SW 1/4 NE 1/4 1/4

Gov't Lot _____ County BENEWAH

Lat: _____ Long: _____

Address of Well Site Shay Hill Rd.

City _____

(Give at least name of road + Distance to Road or Landmark)

Lt. _____ Bk. _____ Sub. Name _____

4. USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation☐ Thermal ☐ Injection ☐ Other _____

5. TYPE OF WORK check all that apply (Replacement, etc.)

☒ New Well ☐ Modify ☐ Abandonment ☐ Other _____

6. DRILL METHOD

☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other _____

7. SEALING PROCEDURES

SEAL/FILTER PACK			AMOUNT	METHOD
Material	From	To	Sacks or Pounds	
BENTONITE	0	60	15 bags	Over bore

Was drive shoe used? ☐ Y ☒ N Shoe Depth(s) _____Was drive shoe seal tested? ☐ Y ☐ N How? _____

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
6	+2	425	250	Steel	☒	☐	☒	☐

Length of Headpipe _____ Length of Tailpipe _____

9. PERFORATIONS/SCREENS

☐ Perforations Method _____☐ Screens Screen Type _____

From	To	Slot Size	Number	Diameter	Material	Casing	Liner

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:

200 ft. below ground Artesian pressure _____ lb.

Depth flow encountered _____ ft. Describe access port or control devices: _____

11. WELL TESTS:

☐ Pump ☐ Bailer ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
5			

Water Temp. _____ Bottom Hole Temp _____

Water Quality test or comments: _____

Depth first Water encountered 200

12. LITHOLOGIC LOG:(Describe repairs or abandonment)

Bore Diam	From	To	Remarks: Lithology, Water Quality, Temperature	Water	
				Y	N
10	0	2	Top Soil	☐	☒
10	2	70	Basalt	☐	☒
8	70	130	Basalt Broken	☐	☒
8	130	170	Basalt w/Tan Clay	☐	☒
8	170	240	Basalt Black	☐	☒
8	240	290	Basaltw/ Gray Clay	☐	☒
8	290	315	Clay Tan	☐	☒
8	315	330	Shale Tan Med	☒	☐
8	330	345	Shale Tan & Green	☐	☒
8	345	425	Shale Dark Gray	☐	☒

RECEIVED
DEC 18 2014
IDWR/NORTHERN

RECEIVED

SEP 14 2001

Department of Water Resources

Completed Depth 425 (Measurable)
Date: Started 6/19/01 Completed 6/22/01

13. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name H2O WellService, Inc. Firm No. 448

Firm Official _____ Date 6-22-01

and

Supervisor or Operator _____ Date 6/22/01

(Sign Once if Firm Official and Operator)

Jim McLeslie

SCANNED

DEC 18 2014