




SINGLEHORN WC SITE MAP
INITIAL SITE LAYOUT FOR CONSERVANCY
NOT ALL DIMENSIONS TO SCALE

Legend
 Building Footprint
 Parking Area
 Irrigation System
 Water Storage Tank
 Well Pump House
 Creek

Water storage tank = 16,800 gal.
concrete tank = 16,800 gal.
steel tank

Well Pump house (drinking water)
3 HP Pump
45 GPM

Location in Creek where irrigation water is taken from
 - 5 HP Pump
 - PH=2, HZ=60, RPM=3510, Volt=230, FLA=22.4, SF=1.15

 = Lawns irrigated

 **McDonald**
A.Y. McDONALD MFG. CO.
4806 Chavanelle Rd. • Dubuque, IA 52002
P.O. Box 508 • Dubuque, IA 52004-C508

23300S

3 HP Pump End

45 GPM

Date **H04**
Code

RETAIN FOR FUTURE USE

Installed by: _____

Attach this nameplate to pump control or
other equipment related to pump in the
well or keep with owner manual

4914X808PM

Pipe coming out

$1\frac{5}{8}" \rightarrow 2\frac{3}{8}"$

Drinking Water Pump