

IDAHO DEPARTMENT OF WATER RESOURCES

WELL DRILLER'S REPORT

RECEIVED

Office Use Only
Inspected by MAR 02 2015
Twp 1/4 Rge 1/4 Sec 1/4
Lat: 43° 14' N Long: 111° 14' W

1. WELL TAG NO. D0010066

DRILLING PERMIT N

Other IDWR No 95-99-N-61

2. OWNER:

Name John Baldwin

Address 10075 N. Government Way / PO Box 741

City Hayden

State ID

Zip 83835

3. LOCATION OF WELL by legal description:

N
Twp 51N North ☒ or South ☐
Rge 03W East ☐ or West ☒
Sec 15 1/4 SE 1/4 SW 1/4
Gov't Lot 10 Ac 40 Ac 160 Ac
County Kootenai
Lat 43° 14' N Long 111° 14' W

Address of Well Site: (see next line)

9506 Syringa

City Hayden

Lot 10 Blk 10

Sub. Name (see next line)

4. USE:

- ☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other

5. TYPE OF WORK check all that apply (Replacement etc.)

- ☒ New Well ☐ Modify ☐ Abandonment ☐ Other

6. DRILL METHOD

- ☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other

7. SEALING PROCEDURES

SEAL/FILTER PACK			Amount	Method
Material	From	To	Sacks/Lbs	
Bentonite	0	59	15 sacks	Dry Pour

Drive Shoe Used? ☒ Y ☐ N Shoe Depth(s) 59

Drive Shoe Seal Tested? ☐ Y ☒ N How?

8. CASING/LINER

Diam	From	To	Gauge	Material	Casng	Liner	Weld	Thrded
6"	1	59	0.25	Steel	☒	☐	☒	☐
4"	-20	380	0.165	PVC	☐	☒	☐	☐
					☐	☐	☐	☐

Length Headpipe Length Tailpipe

9. PERFORATIONS/SCREENS

- ☐ Perforations? Method
☐ Screens? Screen Type

From	To	Slot	Nmbr	Diam	Material	Casng	Liner
						☐	☐
						☐	☐
						☐	☐

10. STATIC WATER LEVEL or ARTESIAN PRESSURE

30 ft. below ground. Artesian pressure lb.

Depth flow encountered 345 ft. Describe access port or

control devices: steel cap welded

11. WELL TESTS:

- ☐ Pump ☐ Bailer ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pump Level	Time
15 est.	100%	380	2 hrs.

Water Temp. cold Bottom hole temp. cold

Water Quality test or comments: (below) Depth first Water Encountered 345
clear

12. LITHOLOGIC LOG (Describe repairs or abandonment)

Bore Diam	From	To	Lithology, Water Quality and Temperature	Water	
				Y	N
8	0	7	Top Soil	☐	☒
8	7	59	Decomposed granite	☐	☒
6	59	145	Decomposed granite	☐	☒
6	145	320	Granite - black/white - medium	☐	☒
6	320	380	Granite - broken black/white - medium	☒	☐
			15 gpm @ 345-350	☐	☐

Completed Depth 380 (Measurable)
Date: Started 6/1/99 Completed 6/2/99

13. DRILLERS CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name United Drilling Inc. Firm No 414

Firm Official Timothy R. Volking Date 6/3/99

Supervisor or Operator Timothy R. Volking Date 6/3/99

FORWARD WHITE COPY TO WATER RESOURCES

51N 3W 15