



All-Ways Drilling Inc.

60 Butler Drive
St. Maries, ID 83861
(208) 245-5003
FAX: (208) 245-1405

Form 235-2, 1/97

Back of Card is Pre Addressed

Idaho Department of Water Resources
1301 North Orchard Boise ID 83706-2237

Write Tag Number Here

D0010573

(Not Valid Without Tag Number)

Start Card/Permit for a Domestic Well

(Cold Water 85 degrees or less)

Press Hard

1. Well Owner (please print): Dave Stornes
2. Owner's Address: 1108 East Homestead
City Coeur d'Alene State Id Zip 83814 Phone 509 276 6137
3. Well Location: Twp: 48N Rge: 2W Sec: 28 1/4 1/4 N/W 1/4 N/W
Gov't Lot No. County Kootenai Lat: Long:
Street Address of Well Site Medmont on Lake Street Cedar House
City Medmont Lot 7-8 Block Sub.

4. Well Construction Information:

☒ New Construction. ☐ Deepen. ☐ Modify. ☐ Replace Existing Well (Previous #)

5. Construction Start Date: 9/7/99 6. Well Driller: All-Ways Drilling License # 510

7. Signature of Driller or Owner: Stornes & Wells Date 9/17/99

Submit White Copy to Department of Water Resources

Applicant agrees to comply with the Underground Facilities Damage Prevention Act I.C. 55-2
number Digline 1-800-345-1585 prior to commencing excavation.

SCANNED

22 2010

Any questions?
Call David Stornes
509 468 9111

OR SEND BACK
I AM 74 AND
TIRED TO ANSWER
THE BEST I
COULD

94-7659

IDAHO DEPARTMENT OF WATER RESOURCES WELL DRILLER'S REPORT

Office Use Only
Inspected by _____
Twp _____ Rge _____ Sec _____
1/4 1/4 1/4
Lat. _____ Long. _____

1. WELL TAG NO. D0010573

DRILLING PERMIT NO. _____
Other IDWR No. _____

2. OWNER:

Name Dave Stammers
Address 1108 East Homestead
City Coreldale State ID Zip 83814

3. LOCATION OF WELL by legal description:

Sketch map location must agree with written location.

N
X
E
S
Twp. 48N North ☒ or South ☐
Rge. 8W East ☐ or West ☒
Sec. 28 1/4 NW 1/4 NW 1/4
Gov't Lot _____ County _____
Lat. _____ Long. _____
Address of Well Site Medmont Lake
Street Cedar House City Medmont
(Give at least name of road - Distance to Road or Landmark)

Sec. 7-8 Blk. _____ Sub. Name _____

4. USE

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other _____

5. TYPE OF WORK check all that apply (Replacement etc.)

☒ New Well ☐ Modify ☐ Abandonment ☐ Other _____

6. DRILL METHOD

☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other _____

7. SEALING PROCEDURES

SEAL FILTER PACK		AMOUNT		METHOD
Material	From	To	Back or Pounds	
<u>Bentonite</u>	<u>-4</u>	<u>83</u>	<u>10</u>	<u>Poured</u>

Was drive shoe used? ☒ N Shoe Depth(s) 83
Was drive shoe seal tested? ☒ Y N How? AIR

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
<u>6"</u>	<u>0</u>	<u>83</u>		<u>Steel</u>	☒	☐	☐	☐

Length of Headpipe +2 Length of Tailpipe 83

9. PERFORATIONS/SCREENS

Perforations Method Drilled
Screens Screen Type _____

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
<u>205</u>	<u>185</u>	<u>1/4</u>	<u>30</u>	<u>1/4</u>	<u>PUC</u>	☐	☒
<u>185</u>	<u>75</u>				<u>PUC</u>	☐	☒

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:

46 ft. below ground Artesian pressure _____ lb.
Depth flow encountered 185 ft. Describe access port or control devices: well cap

11. WELL TESTS:

☒ Pump ☐ Bailor ☒ Flowing Artesian

Yield gal/min	Drawdown	Pumping Level	Time
<u>20</u>			

Water Temp. 56° Bottom hole temp. _____
Water Quality test or comments: good Depth first Water Encounter 185

12. LITHOLOGIC LOG: (Describe repairs or abandonment)

Bore Dia	From	To	Remarks: Lithology, Water Quality & Temperature	Y	N
<u>8"</u>	<u>0</u>	<u>83</u>	<u>Clay Broken Basalt</u>		
<u>6"</u>	<u>83</u>	<u>125</u>	<u>Broken Basalt</u>		
<u>6"</u>	<u>125</u>	<u>135</u>	<u>Single</u>		
<u>6"</u>	<u>135</u>	<u>185</u>	<u>Hard Basalt</u>		
<u>6"</u>	<u>185</u>	<u>200</u>	<u>Broken Basalt</u>		
<u>6"</u>	<u>200</u>	<u>225</u>	<u>Hard Basalt</u>		

Completed Depth 225 (Measurable)
Date: Started 9/7/99 Completed 9/8/99

13. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name Always Drilling Firm No. 510
Firm Official Stanley Wolfe Date 9/13/99
and
Driller or Operator Craig Smith Date 9/8/99
(Sign once if Firm Official & Operator)