

Identify

Identify from:
Taxlots

Taxlots
GOITIA, LAURENCE A

Location:
2,281,680.309 1,814,872.985 Meter

Field	Value
ID	4164183
UPDATED	5/19/2014
PIN	48N04W189200
OWNER	GOITIA, LAURENCE A
ADDRESS1	22127 CRESTLINE TRL
ADDRESS2	
CITY	SANTA CLARITA
STATE	CA
ZIPCODE	91390-5298
P_ADDRESS	19750 S PROVIDENCE LN
P_ZIPCODE	
SUB_NAME	
LEGAL1	TAX #21157 [IN SE-SE]
LEGAL2	534- IMP RES RURAL TRACT
LEGAL3	
LEGAL4	
LEGAL5	
LEGAL6	<null>
ACRES	10
COUNTY	Kootenai
SOURCE	
YEAR_BUILT	1995

Identified 1 feature

Table Of Contents
Identify

POSTED

IDAHO DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORT

Use Typewriter
or
Ball Point Pen

1. DRILLING PERMIT NO. 95 - 94 - N - 225 - 000
Other IDWR No. _____

2. OWNER:

Name HOWARD BIGGS
Address 22 W 37TH ST
City SPOKANE State WA Zip 99203

3. LOCATION OF WELL by legal description:

Sketch map location must agree with written location.

Twp. 48 North ☒ or South ☐
 Rge. 04 East ☐ or West ☒
 Sec. 18 1/4 SE 1/4 SE 1/4
 Gov't Lot _____ County Kootenai
10 acres 40 acres 160 acres

Address of Well Site

(Give at least name of road + Distance to Road or Landmark)

Lt. _____ Blk. _____ Sub. Name _____

4. PROPOSED USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other

5. TYPE OF WORK

☒ New Well ☐ Modify or Repair ☐ Replacement ☐ Abandonment

6. DRILL METHOD

☐ Mud Rotary ☒ Air Rotary ☐ Cable ☐ Other

7. SEALING PROCEDURES

SEAL/FILTER PACK			AMOUNT	METHOD
Material	From	To	Sacks or Pounds	
Bentonite	0	23	7 bags	Dry

Was drive shoe used? Y ☒ N ☐ 6"
Was drive shoe seal tested? Y ☒ N ☐ How? Drove 285'

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
8"	+1	23	250	Steel	☒	☐	☐	☐
6"	+2	285	250	Steel	☒	☐	☐	☐
4"	-265	525	160	PSI PVC	☐	☒	☐	☐

Length of Headpipe _____ Length of Tailpipe _____

9. PERFORATIONS/SCREENS

☒ Perforations Method Skill 1 Saw

☐ Screens Screen Type

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
485	525	1/8x4	120	4"	PVC	☐	☒
						☐	☐
						☐	☐

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:

405 ft. below ground Artesian pressure _____ lb.
Depth flow encountered _____ ft. Describe access port or
control devices:

11. WELL TESTS:

☐ Pump ☐ Bailer ☒ Air ☐ Flowing Artesian

Yield gal/min.	Drawdown	Pumping Level	Time
20 gpm			2 hrs

Water Temp. _____ Bottom hole temp. _____

Water Quality test or comments: _____

12. LITHOLOGIC LOG: (Describe repairs or abandonment)

Bore Dia.	From	To	Remarks: Lithology, Water Quality & Temperature	Y	N
10	0	9	TOP SOIL SANDY Lome		X
10	9	12	BASALT BROKEN GRAY		X
10	12	18	CLAY TAN		X
10	18	23	SAND CLAYISH BROWN		X
8	23	45	BASALT HONEY COMP W/WATER		
			APPROX 2 GPM	X	
8	45	132	BASALT DARK GRAY		X
8	132	138	CLAY DARK GRAY		X
8	138	149	CLAY GRAYISH BROWN		X
8	149	165	CLAY BLUE & GREENISH BROWN		X
8	165	172	CLAY BLUE		X
8	172	175	CLAY ORANGISH BROWN		X
8	175	184	CLAY LIGHT BROWN		X
8	184	188	CLAY TAN		X
8	188	192	CLAY ORANGISH BROWN		X
8	192	285	CLAY TAN W/SAND W/MICA		X
6	285	312	GRANITE DECOMP WHITE & BROWN		X
6	312	349	GRANITE BLACK & WHITE & COPPER		X
6	349	362	GRANITE WHITE & LIGHT COPPER		X
6	362	386	GRANITE BLACK & COPPER		X
6	386	388	GRANITE WHITE W/MICA		X
6	388	417	GRANITE BLACK & COPPER W/MICA		X
6	417	432	GRANITE BLACK W/GREEN		X
6	432	438	GRANITE BLACK		X
6	438	445	GRANITE WHITE W/MICA		X
6	445	460	GRANITE BLACK W/GREEN		X
6	460	479	GRANITE WHITE W/LT-BROWN		X
6	479	495	GRANITE BLACK & COPPER		X
6	495	503	GRANITE WHITE & GREEN		X
6	503	515	GRANITE BLACK & COPPER		X
6	515	518	GRANITE BLACK & COPPER		
			W/WATER 20 GPM	X	
6	518	525	GRANITE BLACK & COPPER		X
Completed Depth			525'	(Measurable)	
Date: Started			10/07/94	Completed 10/11/94	

13. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name H2O WELL SERVICE INC Firm No. 448

Firm Official Blair Johnson Date 10-18-94

and
Supervisor or Operator LEK Date 10-17-94

(Sign once if Firm Official & Operator)

FORWARD WHITE COPY TO WATER RESOURCES