

IDAHO DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORT

Office Use Only			
Inspected by			
Twp	Rge	Sec	
1/4	1/4	1/4	
Lat	:	:	Long

1. WELL TAG NO. D0039656

Drilling Permit No: 826014

Other IDWR No. _____

2. OWNER

Name Spencer, Dave


Address PO Box 1103

City Hayden State ID Zip 83835

Well Number: 870

3. LOCATION OF WELL by legal description

sketch map location must agree with written location



Twp. 48 ☒ North or ☐ South

Rge. 05 ☐ East or ☒ West

E Sec. 10 1/4 NW 1/4 NW 1/4

Gov't Lot _____ County KOOTENAI

Lat: : : Long: : :

Address of Well Site 16955 Painted Rose Road
City Worley

(Give at least name of road + Distance to Road or Landmark)

Lt. _____ Blk. _____ Sub. Name _____

4. USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation

☐ Thermal ☐ Injection ☐ Other _____

5. TYPE OF WORK check all that apply (Replacement, etc.)

☒ New Well ☐ Modify ☐ Abandonment ☐ Other _____

6. DRILL METHOD

☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other _____

7. SEALING PROCEDURES

SEAL/FILTER PACK			AMOUNT	METHOD
Material	From	To	Sacks or Pounds	
BENTONITE	0	18	150 lbs	Overbore

Was drive shoe used? ☒ Y ☐ N Shoe Depth(s) 18

Was drive shoe seal tested? ☐ Y ☒ N How? _____

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner Welded	Threaded
6	+2	18	.250	Steel	☒	☐	☐

Length of Headpipe _____ Length of Tailpipe _____

9. PERFORATIONS/SCREENS

☐ Perforations Method _____

☐ Screens Screen Type _____

From	To	Slot Size	Number	Diameter	Material	Casing	Liner

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:

80 ft. below ground Artesian pressure _____ lb.

Depth flow encountered _____ ft. Describe access port or control devices: _____

48N 5W 10

11. WELL TESTS:

☐ Pump ☐ Bailor ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
1-1 1/2			1hr

Water Temp. Cold _____ Bottom Hole Temp Cold _____

Water Quality test or comments: Clear

Depth first Water encountered 80

12. LITHOLOGIC LOG:(Describe repairs or abandonment)

				Water	
Bore Diam	From	To	Remarks: Lithology, Water Quality, Temperature	Y	N
8	0	18	Granite White/Copper w/Black	☐	☒
6	18	75	Granite White/Copper w/Black	☐	☒
6	75	85	Granite White/Copper w/Black	☒	☐
6	85	126	Granite White/Copper w/Black	☐	☒
6	126	151	Granite White w/Black	☐	☒
6	151	166	Granite White	☐	☒
6	166	248	Granite White w/Black	☐	☒
6	248	312	Granite Black w/White	☐	☒
6	312	401	Granite White w/Black	☐	☒
6	401	419	Granite White	☐	☒
6	419	442	Granite White w/Black	☐	☒

RECEIVED

FEB 28 2005

IDWR/North

RECEIVED

JUL 14 2004

IDWR/North

SCANNED

JUL 22 2015

Completed Depth 442 (Measurable)

Date: Started 11/9/2004 Completed 11/10/2004

13. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name H2O WellService, Inc. Firm No. 448

Firm Official Todd Morgan Date 11-12-04

and

Supervisor or Operator Todd Morgan Date 11/11/04

Todd Morgan

(Sign Once if Firm Official and Operator)