

Identify

Identify from: Taxlots

Taxlots
AUFFANT LIVING TRUST,

Location: 2,288,285.789 1,816,815.242 Meter

Field	Value
ID	5243214
UPDATED	9/28/2015
PIN	48N04W117980
OWNER	AUFFANT LIVING TRUST,
ADDRESS1	930 S COWLEY ST #401
ADDRESS2	
CITY	SPOKANE
STATE	WA
ZIPCODE	99202
P_ADDRESS	16685 S LEANING PINE TREE PT
P_ZIPCODE	
SUB_NAME	
LEGAL1	TX #14431 (IN GOVT LT 2)
LEGAL2	
LEGAL3	
LEGAL4	
LEGAL5	
LEGAL6	<null>
ACRES	0
COUNTY	Kootenai
SOURCE	
YEAR_BUILT	2007

Identified 1 feature

Table Of Contents Identify

Form 236-7 IDAHO DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORT

1. WELL TAG NO. D 0054331
DRILLING PERMIT NO 750433
Water Right or Injection Well No.

ENTERED

2. OWNER:

Name ACCENT BUILDERS
Address 11321 N EASTSHORE DRIVE
City HAYDEN State ID Zip 83835

3. LOCATION OF WELL by legal description:

You must provide address or Lot, Blk, Sub. Or Directions to Well.

Twp. 48 North ☒ or South ☐
Rge. 04 East ☐ or West ☒
Sec. 11 NW 1/4 SE 1/4

Gov't Lot County KOOTENAI

Lat. : Long. :

Address of Well Site 16685 LEANING PINE TREE POINT

City HARRISON

Lt. Blk. Sub. Name

4. USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other

5. TYPE OF WORK check all that apply

☒ New Well ☐ Modify ☐ Abandonment ☐ Other

6. DRILL METHOD:

☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other

7. SEALING PROCEDURES

Seal Material	From	To	Weight/Volume	Seal Placement Method
BENTONITE	0	20	5 SACKS	OVERBORE

Was drive shoe used? ☒ Y ☐ N Shoe Depth(s) 118'

Was drive shoe seal tested? ☒ Y ☐ N How? AIR PRESSURE

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Welded	Threaded
6"	+2	118	.250	STEEL	☒	☐	☒

Length of Headpipe 120' Length of Tailpipe N/A
Packer ☐ Y ☒ N Type

9. PERFORATINS/SCREENS PACKER TYPE

Perforation Method		N/A					
Screen Type & Installation							
From	To	Slot Size	Number	Diameter	Material	Casing	Linear

10. FILTER PACK

Filter Material	From	To	Weight/Volume	Placement Method
N/A				

11. STATIC WATER LEVEL OR ARTESIAN PRESSURE:

68 Ft. below ground Artesian pressure lb.
Depth flow encountered ft. Describe access port or control devices:
STEEL CAP. WELDED & BOLT ON CAP.

Office Use Only			
Well ID No.			
Twp	Rge	Sec	
1/4		1/4	1/4
Lat:		Long:	

12. Well Tests:

☐ Pump ☐ Baller ☒ Air ☐ Flowing Artesian

Yield gal/min.	Drawdown	Pumping Level	Time
12			

Water Temp. COLD Bottom hole temp COLD

Water Quality test or comments: APPEARS CLEAR W/NO ODOR

Depth first Water Encounter 118

13. LITHOLOGIC LOG: (Describe repairs or abandonment)

Bore Dia.	From	To	Remarks: Lithology, Water Quality & Temperature	Y	N
8	0	24	BASALT COBBLES & CLAY		X
8	24	38	BASALT, BLACK, BROKEN		X
8	38	75	BASALT, BLACK, HARD		X
8	75	116	CLAY, BROWN W/COARSE SAND		X
8	116	118	BASALT, BROKEN	X	
6	118	124	BASALT, BROKEN	X	

RECEIVED
JAN 2
IDWR/North

Completed Depth 124' (Measurable)
Date: Started 1/07/08 Completed 1/08/08

14. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Company Name AMERICAN WELL DRILLING Firm No. 675
Principal Driller Date 1-15-08
And
Driller or Operator II Date 1-15-08
Operator I Date
Principal Driller and Rig Operator Required
Operator I must have signature of Driller/Operator II

48N 4W 11