

IDAHO DEPARTMENT OF WATER RESOURCES

WELL DRILLER'S REPORT

77783

Office Use Only			
Inspected by			
Twp	Rge	Sec	
1/4	1/4	1/4	
Lat	:	:	Long

1. WELL TAG NO. D5084

Drilling Permit No: 95-98-N-119

Other IDWR No.

2. OWNER

Name BRANDS, FRANK

Well Number:


744

Address 10620 REED RD

City HAYDEN State ID Zip 83835

3. LOCATION OF WELL by legal description

sketch map location must agree with written location

Twp. 50 ☒ North or ☐ SouthRge. 02 ☐ East or ☒ West

Sec. 18 1/4 NW 1/4 NE 1/4

Gov't Lot County KOOTENAI

Lat: : Long: :

Address of Well Site BLUE CREEK

City CDA

(Give at least name of road + Distance to Road or Landmark)

Lt. Blk. Sub. Name

4. USE:

- ☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other

5. TYPE OF WORK check all that apply (Replacement, etc.)

- ☒ New Well ☐ Modify ☐ Abandonment ☐ Other

6. DRILL METHOD

- ☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other

7. SEALING PROCEDURES

SEAL/FILTER PACK			AMOUNT	METHOD
Material	From	To	Sacks or Pounds	
BENTONITE	0	18	4/1	Granular/Slurry

Was drive shoe used? ☒ Y ☐ N Shoe Depth(s) 79Was drive shoe seal tested? ☐ Y ☐ N How?

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
6	+5	79	.250	STEEL	☒	☐	☒	☐
4	-7	-304	.160	PVC	☐	☒	☐	☐

Length of Headpipe Length of Tailpipe

9. PERFORATIONS/SCREENS

- ☒ Perforations Method SKILLSAW

- ☐ Screens Screen Type

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
264	304	1/8X6	80	4	PVC	☐	☒

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:

110 ft. below ground Artesian pressure lb.

Depth flow encountered ft. Describe access port or control devices:

50 N 2 W 18

11. WELL TESTS:

- ☐ Pump ☐ Bailor ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
5.5			2 HR

Water Temp. COLD Bottom Hole Temp

Water Quality test or comments: CLEAR

Depth first Water encountered 89'

12. LITHOLOGIC LOG:(Describe repairs or abandonment)

				Water	
Bore Peg	From	To	Remarks: Lithology, Water Quality, Temperature	Y	N
8	0	1	Topsoil	☐	☒
8	1	79	Clay Tan W/Shale	☐	☒
6	79	101	Shale Gray 1.5 gpm	☒	☐
6	101	123	Shale Gray 3 gpm	☒	☐
6	123	224	Shale Gray	☐	☒
6	224	304	Shale Gray 1 gpm	☒	☐

RECEIVED

AUG 19 1998

NORTHERN REGION
IDWRCompleted Depth 304' (Measurable)
Date: Started 7/28/98 Completed 7/30/98

13. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name 120 Well Service, Inc. Firm No. 448

Firm Official Date 7/30/98

and Supervisor or Operator Date 7/30/98

(Sign Once if Firm Official and Operator)

(Todd Morgan)

SCANNED
MAR 23 2016