Form 238-7
1994

POSTED

IDAHO DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORT

Use Typewriter or Ball Point Pen

1. DRILLING PERMIT NO. 95 - 94 - N - 0137 - 000
Other IDWR No.

2. OWNER:
Name BILL VICTOR
Address 21102 SE 287TH STREET
City KENT State WA Zip 98042

3. LOCATION OF WELL by legal description:
Sketch map location must agree with written location.

N / W / E / S — X

Twp. 48 North ☒ or South ☐
Rge. 04 East ☐ or West ☒
Sec. 23, 10 acre 1/4 NW 1/4 NW 160 acre 1/4
Gov't Lot ____ County Kootenai

Address of Well Site Powderhorn
(Give at least name of road + Distance to Road or Landmark) City

Lt. Blk. Sub. Name

4. PROPOSED USE:
☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other

5. TYPE OF WORK
☒ New Well ☐ Modify or Repair ☐ Replacement ☐ Abandonment

6. DRILL METHOD
☐ Mud Rotary ☒ Air Rotary ☐ Cable ☐ Other

7. SEALING PROCEDURES

SEAL/FILTER PACK Material	From	To	AMOUNT Sacks or Pounds	METHOD
Bentonite	0	22	8 sacks	Crumbles

Was drive shoe used? Y ☒ N ☐
Was drive shoe seal tested? Y ☐ N ☒ How?

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
6"	+2	22	.250	Steel	☒	☐	☒	☐
4"	+1	59	.160	PVC	☐	☒	☐	☐
					☐	☐	☐	☐

Length of Headpipe Length of Tailpipe

9. PERFORATIONS/SCREENS
☒ Perforations Method Saw Cut
☐ Screens Screen Type

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
39	59	1/16	30	4"	PVC	☐	☒
						☐	☐
						☐	☐

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:
30' ft. below ground Artesian pressure ____ lb.
Depth flow encountered ____ ft. Describe access port or control devices:

NWNW 23 48N 4W

11. WELL TESTS:
☐ Pump ☐ Bailer ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
10			1 1/2 hrs

Water Temp. Cold Bottom hole temp.
Water Quality test or comments:

12. LITHOLOGIC LOG: (Describe repairs or abandonment)

Bore Dia.	From	To	Remarks: Lithology, Water Quality & Temperature	Water Y	Water N
8	0	2	TOP SOIL DARK BROWN SOFT		X
8	2	14	GRAVELS COARSE SANDS BROWN SOFT		X
8	14	22	CLAYS BROWN SOFT		X
6	22	27	BASALT BLACK MEDIUM		X
6	27	33	CLAYS TAN SOFT		X
6	33	75	DECOMPOSED BASALT LIGHT BROWN BROKEN	X	
			GRAVEL PACK FROM SURFACE TO 60'		
			LINER AT SURFACE		
			PLASTIC WELL CAP		

RECEIVED
AUG 1 1994
NORTHERN REGION
IDWR

59'

Completed Depth (Measurable)
Date: Started 07/15/94 Completed 07/16/94

13. DRILLER'S CERTIFICATION
I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name H2O WELL SERVICE INC Firm No. 448
Firm Official John Weber Date 7-27-94
and
Supervisor or Operator Mark L. Lee Date 7-27-94
(Sign once if Firm Official & Operator)

FORWARD WHITE COPY TO WATER RESOURCES

SCANNED
MAR 2 5 2016