Form 238-7
1/94

POSTED

IDAHO DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORT

Use Typewriter or Ball Point Pen

RECEIVED
AUG 19 1994
NORTHERN REGION
IDWR

1. DRILLING PERMIT NO. 95 - 94 - N 134 - 000
Other IDWR No.

2. OWNER:
Name RAY OLIVER #3
Address S. 1300 GREENSFERRY RD.
City COEUR D'ALENE State ID Zip 83814

3. LOCATION OF WELL by legal description:
Sketch map location must agree with written location.

N / W / E / S

Twp. 50N North ☒ or South ☐
Rge. 5W East ☐ or West ☒
Sec. 24, SE 1/4 NW 1/4 (10 acres) SW 1/4 (160 acres)
Gov't Lot 17 County KOOTENAI

Address of Well Site RIDGELINE ESTATES City CDA
(Give at least name of road + Distance to Road or Landmark)

Lt. 17 Blk. 2 Sub. Name RIDGELINE ESTATES

4. PROPOSED USE:
☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other

5. TYPE OF WORK
☒ New Well ☐ Modify or Repair ☐ Replacement ☐ Abandonment

6. DRILL METHOD
☐ Mud Rotary ☒ Air Rotary ☐ Cable ☐ Other

7. SEALING PROCEDURES

SEAL/FILTER PACK Material	From	To	AMOUNT Sacks or Pounds	METHOD
BENTONITE	0	20	6	OVERBORE

Was drive shoe used? Y ☒ N ☐
Was drive shoe seal tested? Y ☐ N ☒ How?

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
6"	0	20	250	STEEL	☒	☐	☒	☐
4"	20	220	160 PSI	PVC	☐	☒	☒	☐
					☐	☐	☐	☐

Length of Headpipe Length of Tailpipe

9. PERFORATIONS/SCREENS
☒ Perforations Method DRILLED
☐ Screens Screen Type

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
120	180	3/8	300	4"	PVC	☐	☒
						☐	☐
						☐	☐

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:
70 ft. below ground Artesian pressure lb.
Depth flow encountered ft. Describe access port or control devices:
Gov't Lot 17 24 50N 5W

11. WELL TESTS:
☐ Pump ☐ Bailer ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
1068m	100%	240	1 hr.

Water Temp. COLD Bottom hole temp. COLD
Water Quality test or comments: CLEAR

12. LITHOLOGIC LOG: (Describe repairs or abandonment)

Bore Dia.	From	To	Remarks: Lithology, Water Quality & Temperature	Water Y	Water N
8"	0	20	DECOMPOSED GRANITE		X
6"	20	60	DECOMPOSED GRANITE		X
	60	95	REDDISH BROWN GRANITE		X
	95	240	BLACK & WHITE BROKEN GRANITE	X	

RECEIVED
JUL 22 1994
NORTHERN REGION
IDWR

SCANNED
APR 20 2016

Completed Depth 240' (Measurable)
Date: Started 6/23/94 Completed 6/24/94

13. DRILLER'S CERTIFICATION
I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name UNITED DRILLING INC. Firm No. 414
Firm Official Tim R Vally OP Date 6-24-94
and
Supervisor or Operator Chris Tenney Date 6/24/94
(Sign once if Firm Official & Operator)

FORWARD WHITE COPY TO WATER RESOURCES