

WELL LOG AND REPORT TO THE
STATE RECLAMATION ENGINEER OF IDAHO

025974

ENT'D

RECEIVED

Log No. JUL 8 1959
Rec'd Dept. of Reclamation
Well No. 95-58-N-1
Permit No.

(DO NOT FILL IN)

Owner Earl H. Stanhope Address Plummer, Ida.
Driller Elmer Ray Address Idaho, Id. Lic. No. 102
Location of Well: Sec. 14, T. 46 N., R. 5 W. County, _____
and _____ feet N/S, and _____ feet E/W from _____ Corner of _____ 1/4 Sec. _____
Size of Drilled Hole 6" Total depth of Well 125 ft
Give depth of standing water from surface 30 Water Temp. 53 F. °Fahrenheit
On pumping test delivery was Bailer test g.p.m. or 25 c.f.s. Drawdown was 70 feet.
Size of pump and motor used to make the test _____
Length of time pumped during check was _____ hr., _____ minutes.
If flowing well, give flow in c.f.s. _____ or g.p.m. _____ and shut in pressure _____
If flowing well, describe control works _____
(TYPE AND SIZE OF VALVE, ETC.)
Water will be used for Drain Weight of casing per linear foot 19.14
Thickness of casing 2 1/2" Casing material New Steel Std. Bkt. Pipe Co.
E.G., PIPE, CONCRETE, WOOD.
Diameter, length and location of casing 6" 54 ft. Set 52 ft.
(CASING 12" IN DIAMETER AND UNDER GIVE INSIDE DIAMETER;
CASING OVER 12" IN DIAMETER GIVE OUTSIDE DIAMETER.)
Number and size of perforations None located _____ feet to _____ feet
from surface of ground.
Other perforations none
Date of commencement of well Oct. 10 Date of completion of well Oct 20 - 58
Type of well rig Bucyrus Erie 60 L.

CASING RECORD

DIAM. CASING	FROM FEET	TO FEET	LENGTH	REMARKS - SEALS, GROUTING, ETC.
6"	1	53	54	carefully Grouted & sealed on out side to keep out all surface water

GENERAL INFORMATION—Pumping Test, Quality of Water, Etc.

Same well Bailer test water good
taste - quite soft & cold
Pump was installed after I moved rig
away.

SE NW 1/4 14 46 N 5 W

SCANNED

AUG 13 2014

95-16088
95-16089

025975

WELL LOG

[illegible]**WELL DRILLERS STATEMENT**

This well was drilled under my jurisdiction and the above information is true and correct to the best of my knowledge and belief.

Signed Elmer Ray
By Elmer Ray

Dated Oct 20, 1954

License No. 102

SCANNED

AUG 13 2014

~~95-16088~~
95-16089