Form 238-7
6/93

ENT'D

IDAHO DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORT

OCT 19 [illegible]

Use Typewriter or Ball Point Pen

153601

1. DRILLING PERMIT NO. 95 - 93 - N 176 - 000
Other IDWR No _____

2. OWNER:
Name COOK'S INC.
Address W2455 HWY 53
City POST FALLS State ID Zip 83854

3. LOCATION OF WELL by legal description:
Sketch map location must agree with written location

N / W / E / S — X in SW quarter

T 48 North ☐ X or South ☐
R 4 East ☐ or West ☒
Sec 5 , ____ 10 acres 1/4 SW 40 acres 1/4 SW 160 acres 1/4
Gov't Lot ____ County KOOTENAI

Address of Well Site OFF OF LOFF's BAY RD
(Give at least Direction – Distance to Road or Landmark)

Lot No ____ Block No ____ Subd Name ____

4. PROPOSED USE:
☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other ____

5. TYPE OF WORK
☒ New Well ☐ Modify or Repair ☐ Replacement ☐ Abandonment

6. DRILL METHOD
☐ Mud Rotary ☒ Air Rotary ☐ Cable ☐ Other ____

7. SEALING PROCEDURES

SEAL/FILTER PACK Material	From	To	AMOUNT Sacks or Pounds	METHOD
BENTONITE		18	12	OVERBORE TO SEAL DEPTH

Was drive shoe seal tested? YES NO How? ____

8. CASING/LINER:

Diameter	From	To	Guage	Casing	Liner	Steel	Plastic	Welded	Threaded
6	+2	18	.250			☐	☐	☒	☐
4	-6	260			160	☐	☒	☒	☒
						☐	☐	☐	☐
						☐	☐	☐	☐

Final location of shoes 18
Top Packer or Headpipe ____ Bottom Tailpipe ____

9. PERFORATIONS/SCREENS
☒ Perforations Method SkillSaw
☐ Screens Type ____ Material ____

From	To	Slot Size	Number	Diameter	Tele/Pipe Size	Casing	Liner
220'	260'	1/8"	100	4"		☐	☒
						☐	☐
						☐	☐
						☐	☐

SW SW sec. 5 T. 48 R. 4 W

10. WELL TESTS: ☐ Pump ☐ Bailer ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Depth	Time
60+			

Temperature of water ____ Was a water analysis done? Yes ☐ No ☐
By whom? ____
Water Quality (odor, etc.) Good
Bottom Hole Temperature ____

11. STATIC WATER LEVEL:
90 ft. below surface Depth artesian flow found ____
Artesian pressure ____ lb. Describe access port ____
Describe Controlling Devices: ____

12. LITHOLOGIC LOG: (Describe repairs or abandonment)

Bore Dia.	From	To	Remarks: Lithology, Water Quality & Temperature	GPM	SWL
8	0	12	TOPSOIL SANDY LOAM		
8	12	18	GRANITE DECOMP BROWN		
6	18	28	GRANITE BROWN & WHITE SOFT		
6	28	57	GRANITE BROWN & WHITE QUARTZ XXXXXX MED		
6	57	81	GRANITE WHITE BRWON W/WATER SOFT	2	
6	81	170	GRANITE BLACK & BROWN MED		
6	170	176	GRANITE BLACK & BROWN W/CLAY SOFT		
6	176	208	GRANITE WHITE & BROWN MED		
6	208	227	GRANITE BLACK & BROWN W/GREEN		
6	227	236	GRANITE BLACK & WHITE HARD		
6	236	250	GRANITE WHITE & BLACK W/GREEN		
6	250	257	GRANITE BLACK & BROWN &WHITE W/WATER	60	
6	257	260	GRANITE BLACK & WHITE HARD		

SEP 29 1993

OCT 26 1993

Date: Started 9-20-93 Completed 9-20-93

13. DRILLER'S CERTIFICATION
I/We certify that all minimum well construction standards were complied with at the time the rig was removed

Firm Name H2O WELL SERVICE, INC. Firm No 448
Firm Official [signature] Date 9-27-93
and
Supervisor or Operator [signature] Date 9-27-93
(Sign once if Firm Official & Operator)

FORWARD WHITE COPY TO WATER RESOURCES