

IDAHO DEPARTMENT OF WATER RESOURCES

WELL DRILLER'S REPORT

Use Typewriter or Ballpoint Pen

Office Use Only			
Inspected by			
Twp	Rge	Sec	
1/4	1/4	1/4	
Lat	:	:	Long

95-98-N-36

1. DRILLING PERMIT NO. TAG#D0003620

Other IDWR No.

2. OWNER

Name SAMPSON, GARY

Well Number:

672

Address 206 OSPREY CT.

City POST FALLS State ID Zip 83854

3. LOCATION OF WELL by legal description

sketch map location must agree with written location

N			
X			
S			

Twp. 50 ☒ North or ☐ SouthRge. 05 ☐ East or ☒ West

E Sec. 12 1/4 SW 1/4 SW 1/4

Gov't Lot County KOOTENAI

Lat: : : Long: : :

Address of Well Site S 1700 GREENSFER

City POST FALLS

(Give at least name of road + Distance to Road or Landmark)

Blk. Sub. Name

4. USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation☐ Thermal ☐ Injection ☐ Other

5. TYPE OF WORK check all that apply (Replacement, etc.)

☒ New Well ☐ Modify ☐ Abandonment ☐ Other

6. DRILL METHOD

☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other

7. SEALING PROCEDURES

SEAL/FILTER PACK			AMOUNT	METHOD
Material	From	To		
BENTONITE	0	18	9 SACKS	GRANULAR

Was drive shoe used? ☒ Y ☐ N Shoe Depth(s) 0Was drive shoe seal tested? ☐ Y ☐ N How?

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
6	+2	166	.250	STEEL	☒	☐	☒	☐
4	-143	243	.160	PVC	☐	☒	☐	☐

Length of Headpipe Length of Tailpipe

9. PERFORATIONS/SCREENS

☒ Perforations Method SKILLSAW☐ Screens Screen Type

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
203	243	1/8X6	100	4	PVC	☐	☒

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:

165 ft. below ground Artesian pressure lb.

Depth flow encountered ft. Describe access port or

control devices: 6" WELL CAP

T50NR5W 12 SW SW

11. WELL TESTS:

☐ Pump ☐ Bailor ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
45+			1 HR

Water Temp. Bottom Hole Temp

Water Quality test or comments:

Depth first Water encountered 190'

12. LITHOLOGIC LOG:(Describe repairs or abandonment)

				Water	
Bore Diam	From	To	Remarks: Lithology, Water Quality, Temperature	Y	N
8	0	64	Sands	☐	☒
8	64	66	Sand W/Granite Gravel	☐	☒
8	66	79	Sands	☐	☒
8	79	84	Sands W/Clay	☐	☒
8	84	140	Sands	☐	☒
8	140	164	Sands W/Pea Gravel	☐	☒
8	164	166	Granite Black White	☐	☒
6	166	178	Granite Black W/White	☐	☒
6	178	190	Decomposed Granite Clay W/Sand	☐	☒
6	190	221	Decomposed Granite	☒	☐
6	221	243	Granite White W/Black	☒	☐
	0	0	4"x6" Formation Packer Placed at 190'	☐	☐

RECEIVED

APR 10 1998

NORTHERN REGION
IDWR

RECEIVED

APR 30 1998

NORTHERN REGION
IDWR
NORTHERN REGION
IDWR

Completed Depth 243' (Measurable)

Date: Started 3/23/98 Completed 3/24/98

13. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name H2O Well Service, Inc. Firm No. 448

Firm Official Date

and

Supervisor or Operator Date 3-26-98

(Sign Once if Firm Official and Operator)

(Todd Morgan)

SCANNED

JUN 27 2016

Identify

Identify from: Taxlots

Taxlots

MEYER, GERALD KENNETH

Location: 2,281,376.685 1,835,914.389 Meters

Field	Value
ID	5239454
UPDATED	9/28/2015
PIN	OK1450010010
OWNER	MEYER, GERALD KENNETH
ADDRESS1	1500 S GREENSFERRY RD
ADDRESS2	
CITY	COEUR D ALENE
STATE	ID
ZIPCODE	83814
P_ADDRESS	1500 S GREENSFERRY RD
P_ZIPCODE	
SUB_NAME	KANS ESTATES
LEGAL1	KANS ESTATES, LT 1 BLK 1 1250N05W
LEGAL2	
LEGAL3	
LEGAL4	
LEGAL5	
LEGAL6	<null>
ACRES	0
COUNTY	Kootenai
SOURCE	
YEAR_BUILT	1998

Identified 1 feature

SCANNED
JUN 27 2016