

WELL DRILLER'S REPORT

JUL 09 2003

1. WELL TAG NO. D0028490

Drilling Permit No: 803048

IDWR/North

2. OWNER

Name BRITTON, RICK

Well Number:


581

Address 9504 E. MARINGO

City SPOKANE State WA Zip 99206

3. LOCATION OF WELL by legal description

sketch map location must agree with written location

Twp. 49 ☒ North or ☐ SouthRge. 3 ☐ East or ☒ West

Sec. 7 1/4 NW 1/4 SW 1/4

Gov't Lot _____ County KOOTENAI

Lat. : : Long. : :

Address of Well Site PANARAMA VIEW

City COEUR D' ALE

(Give at least name of road + Distance to Road or Landmark)

Lt. 3 Blk. _____ Sub. Name _____

4. USE:

- ☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other _____

5. TYPE OF WORK check all that apply (Replacement, etc.)

- ☒ New Well ☐ Modify ☐ Abandonment ☐ Other _____

6. DRILL METHOD

- ☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other _____

7. SEALING PROCEDURES

SEAL/FILTER PACK			AMOUNT	METHOD
Material	From	To	Sacks or Pounds	
DRY GRANULE				
BENTONITE	0	18	20 BAGS	OVERBORE

Was drive shoe used? ☐ Y ☒ N Shoe Depth(s) R.B.Was drive shoe seal tested? ☐ Y ☒ N How? _____

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
6	+4	120	.250	STEEL	☒	☐	☒	☐

Length of Headpipe _____ Length of Tailpipe _____

9. PERFORATIONS/SCREENS

☐ Perforations Method _____☐ Screens Screen Type _____

From	To	Slot Size	Number	Diameter	Material	Casing	Liner

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:

75 ft. below ground Artesian pressure _____ lb.

Depth flow encountered 155 ft. Describe access port or control devices: _____

11. WELL TESTS:

- ☐ Pump ☐ Bailor ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
10 - 15			1 HR

Water Temp. COLD Bottom Hole Temp. COLD

Water Quality test or comments: CLOUDY

Depth first Water encountered 155

12. LITHOLOGIC LOG:(Describe repairs or abandonment)

Sore Diam	From	To	Remarks: Lithology, Water Quality, Temperature	Water	
				Y	N
8	0	1	Top Soil	☐	☐
8	1	13	Tan Clay	☐	☐
8	13	19	Clay w/ Basalt	☐	☐
8	19	120	Broken Basalt	☐	☐
6	120	131	Basalt	☐	☐
6	131	150	Brown Clay	☐	☐
6	150	160	Sand	☒	☐

Completed Depth 120 (Measurable)

Date: Started 6/2/03 Completed 6/4/03

13. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name H2O Well Service, Inc. Firm No. 448

Firm Official _____ Date 6-6-03

and Supervisor or Operator _____ Date 6-6-03

(Sign Once if Firm Official and Operator)

(Todd Morgan)

49N 3W 7